PHOENIX MEMORIAL LABORATORY

MEMORANDUM REPORT NO. 4

Calculation of Radiation Dose Rates From Fission

Products In The Ford Nuclear Reactor

By: J. B. Bullock

Michigan Memorial Phoenix Project

The University of Michigan

November 1962

Michigan

INTRODUCTION

Calculations are given for estimating the gamma-radiation dose rate due to an unshielded core in the empty pool of the FNR. The calculations were made in order to estimate consequences of an accident which would cause the water to drain out of the pool. The calculations are based on the methods of Stephenson.*

The equations were programmed in the MAD language for use on The University of Michigan IBM-7090 computer. The programs are given in Appendices A and B.

The assumptions made in the approach are:

- 1. The reactor is a point source.
- 2. The fission product inventory is due to 2 MW operation for 10^7 seconds.
- 3. The reactor has been shut down for 10 minutes.
- 4. Radiation outside the direct beam is due to single scattering from:
 1) the pool walls, 2) the building walls, 3) the building ceiling and 4) the building air.

5. Air absorption and pair production may be neglected.

GENERAL EQUATIONS FOR SLAB SCATTERING

Consider a mono-energetic gamma beam of intensity I_0 and cross-sectional area A_b , incident an a unit slab. See Figure 1. Assume Σ_1 and Σ_2 to be the total macroscopic cross sections of the slab material for the incident and scattered radiation, I_0 and 1. At a distance t below the surface of a slab of density ρ , the mass of a small scattering element dt as seen by I_0 is ρ Sec θ_1 dt and the radiation intensity at the depth t is:

$$I_{t} = I_{o} e^{-\Sigma_{1} t \operatorname{Sec} \Theta_{1}}$$
(1)

* Stephenson, R., "Introduction to Nuclear Engineering", (pgs. 193–200) McGraw-Hill, New York, 1954 Similarly the fraction of the scattered radiation reaching the surface is

$$e^{-\Sigma}2^{\dagger} \sec \theta 2$$
 (2)

If we now assume the scattering phenomena to be adequately described by the Klein-Nishina formula we may write:

$$I = \frac{N A_b Sec \theta}{C^2} \frac{d \sigma}{d \Omega} \int_0^t e^{-(\Sigma_1 Sec \theta} + \Sigma_2 Sec \theta} 2^{t} dt \qquad (3)$$

where I is the intensity at a detector located a distance C from the scattering slab_q N is the electron density of the slab and $\frac{d}{d} \frac{\sigma}{\Omega}$ is the differential Klein-Nishina

cross section.

$$\frac{d \sigma}{d \sigma} = \frac{2}{\sigma} (P - P^{2} \sin^{2} \phi + P^{3}) \qquad (4)$$

$$\frac{E}{d \Omega} = \frac{1}{E_{0} + \frac{E_{0}(1 - \cos \phi)}{1 + \frac{E_{0}(1 - \cos \phi)}{0}} \qquad (5)$$

where E_{o} is the incident gamma energy, E is the scattered gamma energy and ϕ is the scattering angle.

After integrating and simplifying (3) becomes:

$$I = \frac{NA_{b}}{C^{2}} \begin{bmatrix} \frac{\Sigma_{1}}{\cos \theta_{1}} + \frac{\Sigma_{2}}{\cos \theta_{2}} \\ \frac{\Sigma_{1} + \Sigma_{2}}{\cos \theta_{2}} \end{bmatrix} \frac{d\sigma}{d\Omega}$$
(6)



Figure 1

Using the approximate expression (page 184, Stephenson);

Dose Rate
$$(r/hr_{\circ}) \approx 1.86 \times 10^{-6} E$$
 (7)

for $E \sim .07$ Mev to ~ 3 Mev, the dose rate may be calculated by evaluating (6) at any detector location of interest where 1 is the number of photons per cm² per sec. The difficulty in applying equation (6) is the requirement that the scattering source approximate a point source. Since the detector is 20 to 30 feet from the scattering planes, this requirement is satisfied by dividing all the scattering walls into 20 cm x 20 cm squares and summing the contribution from each square. This is the calculation carried out by the program shown in Appendix A.

GENERAL EQUATION FOR AIR SCATTERING

The air scattering problem is simplified by neglecting absorption in air which also tends to compensate for the error in neglecting secondary scattering. However, the calculation is more laborious because of the necessity of volumetric integration. The equation used here is:

$$I = \frac{NS}{4\pi d_1 C^2} \frac{d \sigma}{d \Omega}$$
(8)

and the new symbols are S = source strength in gammas per second, d_1 = distance from source to scattering volume dx dy dz. For this calculation the unit volume selected was 50 cm x 50 cm x 50 cm. This calculation was performed with the aid of the program shown in Appendix B.

SOURCE CHARACTERISTICS

The source characteristics were taken from Blomeke and Todd^{*} where four energy groups are given. The maximum energy was used for each energy group. The source characteristics for the assumed power history are given in Table 1.

Group	Energy (Mev)	<u>S (photons/sec)</u>
1	.25	3.51×10^{16}
	1.0	7.39 × 10 ¹⁶
	1.7	2.21×10^{16}
IV	3,0	0.70×10^{16}

Table 1 - Source Characteristics

 * ORNL-2127, Part 1 Volume 2, "Uranium-235 Fission-Product Production As A Function Of Thermal Neutron Flux, Irradiation Time, And Decay Time."
 J. O. Biomeke and Mary F. Todd

 \frown

RESULTS

Using equation (7) and the source values shown in Table 1, the gamma dose rate in the direct beam at the reactor bridge was estimated to be 9100 r/hr. In addition, estimates were made for the delayed neutron contribution to the dose rate in the direct beam. The results indicate that neutron dose rate is less than 100 mrem/hr.

Using the computer program shown in Appendices A and B, calculations for scattered radiation dose rates were performed for two detector locations. The location labeled "Inside Building" in Table 2 is considered to be representative of locations of interest in the reactor building. This location is 6 feet above the operating floor at the west wall of the reactor building. Contributions to the dose rate at this location are as follows: the interior south wall of the reactor building it he inside edge of the reactor pool wall; the ceiling of the reactor building and the interior north wall of the reactor building. The dose rate contribution from these individual scattering planes is indicated in the following table.

The location labeled "Outside Building" is considered to be a typical location of interest. The point lies 10 feet to the west of the building at the operating floor elevation which is 10 feet above the ground level.

In addition to the wall scattering contribution, the contribution from radiations scattered by the air in the reactor building is also presented in the table of results.

-6-

Table 2 - Radiation Dose Rates

Scattering Source	Dose Rate (r/hr) Inside Building	Dose Rate (r/hr) Outside Building
Air	41.0	7.8
South Wall	13_3	7.5
Ceiling	8.8	5.1
North Wall	14.8	8,7
Pool Walls	82.3	0.0
TOTAL	160,2	29.1
		* Note
		\checkmark

The calculations for the detector located exterior to the building have neglected the presence of the reactor building walls which are concrete 12 inches thick. This is a tenth thickness value for 3 Mev gammas, hence a reduction in the dose rates by a factor of 10 is considered to be conservative.

APPENDIX A

962 VERSION) PROGRAM LISTING

DCAD DATA	n e constante de la constante d
KEAU DATA	
PRINT RESULTS DELX, DELY, DELZ, XD, YD,	2 ZD. ZF. YW, WP, KON, CASE
RHENEVER LASE.E.	and a second
AI = CAI	
$MI = UXI \oplus UXI$	
$R_{\ell} = LAI$	
VZ = VELZ	
DC = XD	and a second of the second of the second of the second of the second second second second second second second
$\underline{DELI = DELY}$	
DELJ = DELZ	
UR WHENEVER CASE.E.2	
XI = CX2	
K1 = CX2 = CX2	
K2 = CX2	na manaka ka pangan ka sa
D1 = DELY	
D2 = DELZ	en e
DC = XD	
DELI = DELY	
DELJ = DELZ	
OR WHENEVER CASE.E.3	nan mana mana mana mana mana mana mana
ZI = CZ	
K1 = CZ + CZ	
$K_2 = CZ$	
D1 = DELX	
D2 = DELY	,
DC = ZD	ang nang ng pang ang ang ang ang ang ang ang ang ang
DELI = DELX	
DELJ = DELY	
OR WHENEVER CASE F.4	
YI = CY	والاحتجاز ومصفح فستعاد ومناجع المراجع المراجع والمراجع والمراجع المراجع والمراجع المراجع والمراجع والمراجع
KI = CY * CY	
$K_2 = CY$	na na sana na s
D1 = DF1X	
$D^2 = DE17$	
O(=V)	
IMIN = 7E - (7D - 7E) = 1004 ADC - 4 MD	
DFII = DFIY	YW)
DFI = DFI 7	and when any only only a constant of an open of the second s
ATHERWISE	
TRANSEED TO STOD	and the second sec
END OF CONDITIONAL	
INTEDNAL FUNCTION 5 101	
WIENAL FUNCTION F. (UI. UZ, KI, VI, VZ)	= D1+D2+K1/(SQRT.(K1+
LATERNAL FUNCTION CONTRACTOR	a second and an
INTERNAL FUNCTION CULT. (K2) = ABS. (K2 / SB)
LOLEKNAL FUNCTION GOZI. 182. DC) = AB	S. (K2-DC)/SC
$IUR = U_{e}U$	
INKUUGH LUUP, FOR VALUES OF EL = 0.25,	1.0, 1.7, 3.0
UUS1 = 1	
WHENEVER EL E. 0.25	
XCT1 = .270	
$S = 3_{5}1E16$	
	المربور والمحادية المراجع المحادي المحادي المحادي المحادي المحادية المحادية المحادية المحادية المحادية المحادية

0

ð

	XCT1 = .1492	
	S = 7.39E16	
	OR WHENEVER EL E. 1.70	
	xCT1 = 120	
1		
J	いれ 続けたきたち とす よとっ きゅひり おんてき ニー ひんちょう	
	AU11 * 0052) C = A 70614	
	FND OF CONDITIONAL	
	THROUGH FIRST FOR $I = IMIN = OFIL I = G = IMAY$	
	THROUGH FIRST, FOR J= JMIN, DELJ, J .G. JMAX	
	WHENEVER CASE.E.I .OR. CASE.E. 2	
	YI = I	
	OR NHENEVER CASE, E. 3	
	X & PE Å	
	NE LINENEVED CAPE F /	
	VN HORMERERA VAGRates	
	OTHERWISE	
	TRANSFER TO STOP	
	END OF CONDITIONAL	
	$A = XO \Rightarrow XO + YO = Y$	
	B = XIEXI - VIEVIE ZIEZI	
	$C = \{XD - XI\} = \{XD - XI\} + \{AD - AI\} + (AD - AI\}$	ŝ
	$\frac{1}{\sqrt{120-21}} = \frac{1}{\sqrt{20-21}}$	
	SC = SOB (C)	
	$\frac{\partial V}{\partial A} = \frac{\partial V}{\partial A} = \frac{V}{\partial A} = $	
)	COS1 = (A - 8 - C) / C2R	
)	$SIN21 = 1.0 - COS1 \approx COS1$	
	P = 1.02 (1.0+EI = (1.6-COS1) (0.511)	
	DKN= .0237 * 1 P -P&P& SIN21 + P .P. 3.01	
-	V1 = I	
	$\sqrt{2} = 1$	
-	AB = COIT (K2) (K1) (Y1) (Y2)	
	$UI = UII_{i}(NZ)$ $CO2 = CO2T iX2 OC2$	
	F = P + FI	
	WHENEVER F .G . 0.00 . END. F .I . 0.10 . XCT2 = .307	
-	WHENEVER E GEO 0.10 AND. E L_{a} 0.15 ALT = 327	
	HHENEVER E GER Qals AND. E al, Qa20 . XCT2 = .291	
	WHENEVER E .GE. 0.20 .AND. E .L. 0.30 , XCT2 = .251	
	HHENEVER E OGEO QO30 OANDO E alo DO40 o XGIZ = 2242	
	WHENEVER E .GE. 0.40 .AND. E .L. 0.50 , $XCT2 = .2045$	
-	HHENEVER E .GE. 0.50 AND. E .L. 0.60 . XCT2 = .1889	
	WHENEVER E .GE. 0.80 .AND. E .L. 0.80 , XCT2 = .1659	
	$\frac{1}{10000000000000000000000000000000000$	
	HIGENEREN E ODEN LOUV NANDN E NEN 1020 P AUIZ # 01332 Whenever F .ge. 1.25 and f i i so vero - toir	
- 4	WHENEVER F GE. 1.50 AND F 1. 2.00 - $V(T2 = 1044$	
	WHENEVER E GE 2.00 AND E 1. 3.00 . $XC12 = .0853$	
	WHENEVER E .GE. 3.00 .AND. E .L. 9.00 . XCT2 = .060	
	18C = S / 1.6.28 * 2.0 * C * B)	
}	NUM = $1.0 - EXP.(1 - XCT1/CO1 - XCT2/CO2) + T$	
	DEN = XCI1 + XCI2 + CO1/ CO2	
	GAMI = KON®AB®(NUM/DEN)®DKN®IBC	
	MHENEVER LAESIMIN SANDSJOESJMINS PRINT RESULTS EIS ISJAGAMIS	
	L LAGE	

9.

APPENDIX B

ŧ

SCOMPILE MAD, PRINT OBJECT, PUNCH OBJECT, EXECUTE, DUMP

MAD (16 APR 1962 VERSION) PROGRAM LIGTING

and a second second

IN READ DATA PRINT RESULTS XD, YD. ZD, DELI, DELJ, DELK, IMAX, IMIN, JMAX, 1 JMIN, KMAX, KMIN IDR = 0.0THROUGH LOOP, FOR VALUES OF EI = 0.25, 1.0, 1.7, 3.0WHENEVER EI .E. 0.25, S = 3.51E16WHENEVER EI .E. 1.00, 5 = 7.39E16WHENEVER E1 . E. 1.70, S = 2.21E15WHENEVER EI .E. 3.00, S = 0.70E160.051 = 0.0THROUGH FIRST, FOR XI = IMIN, DELI, XI .G. IMAX THROUGH FIRST, FOR YI = JMIN, DELJ, YI .J. JMAX THROUGH FIRST, FOR ZI = KMIN, DELK, ZI .G. KMAX $A = XD \neq XD + YD \neq YD \neq ZD \neq ZD$ E = XI = XI + YI = YI = ZI = ZI C = (XD - XI) * (XD - XI) + (YD - YI) * (YU - YI) * (ZD - ZI) * (ZD - ZI) $SH = SQRT_{0}$ (B) SC = SQRT. (C)C2B = 2.0 = SB = SCCOS1 = (A - B - C) / C2B. SIN21 = 1.0 - COS1 + COS1P = 1.0 / (1.0+EI *(1.0-COS1)/0.511) $E = P \neq EI$ DKN = 0.0237 = (P-P=P=SIN21 + P .P. 3.0) GAMI = 4.77E-05 * S * DKN «DELI»DELJ«DELK/ (8*C) WHENEVER XIZE. IMIN. AND. YI.E. JMIN. AND. ZI.E. KMIN. PRINT RESULTS 1 EL , XL, YL, ZL, GAMI FIRSE UOSI = DOSI + 1.86E-06 * E * GAMI PRINT RESULTS EI, DOSI, XD, YD, ZD LUOP TUR = TDR + UOSI PRINT RESULTS TOR, XD, YD, ZD TRANSFER TO IN STOP END OF PROGRAM

THE FOLLOWING NAMES HAVE OCCURRED ONLY ONCE IN THIS PROGRAM. COMPILATION WILL CONTINUE.

STOP