

UMTRI-86-32

**FILTER CHARACTERISTICS
FOR PROCESSING BIOMECHANICAL SIGNALS
FROM IMPACT TESTS**

Nabih M. Alem

The University of Michigan
Transportation Research Institute
Ann Arbor, Michigan 48109

FILTER STUDY FINAL REPORT

July 1986

Prepared under Contract No. DTNH22-83-C-0-7005

The Engineering Design, Development, Testing, and Evaluation
of an Advanced Anthropomorphic Test Device

National Highway Traffic Safety Administration
Department of Transportation
Washington, D.C. 20590

This document is disseminated under the sponsorship of the Department of Transportation in the interest of information exchange. The United States Government assumes no liability for the contents or the use thereof.

Technical Report Documentation Page

1. Report No.	2. Government Accession No.	3. Recipient's Catalog No.	
4. Title and Subtitle FILTER CHARACTERISTICS FOR PROCESSING BIOMECHANICAL SIGNALS FROM IMPACT TESTS		5. Report Date July 1986	6. Performing Organization Code
		8. Performing Organization Report No. UMTRI-86-32	
7. Author(s) Nabih M. Alem		10. Work Unit No.	11. Contract or Grant No. DTNH22-83-C-07005
9. Performing Organization Name and Address The University of Michigan Transportation Research Institute 2901 Baxter Road Ann Arbor, Michigan 48109		13. Type of Report and Period Covered FINAL REPORT	
		14. Sponsoring Agency Code	
12. Sponsoring Agency Name and Address U.S. Department of Transportation National Highway Traffic Safety Administration Washington, D.C. 20590		15. Supplementary Notes This work, initially started in 1983 as part of the Advanced Anthropomorphic Test Device Project, was finalized in April-June 1986.	
16. Abstract Digital signals generated in head and chest impact tests were used as the basis for characterizing the frequency responses of the human head and chest, and for specifying filters for the data acquisition and analysis of such signals. Spectral analysis of about 450 signals resulted in some 23 approximate characterizations that were further combined into three final recommendations. Each recommended filter is a low-pass Butterworth filter specified by its -3 dB corner (Hertz) and the slope of its rolloff asymptote (dB/decade). The three recommended filters are: HEAD signals: Corner = 550 Hz, Slope = -26 dB/dec. CHEST (anti-alias): Corner = 500 Hz, Slope = -27 dB/dec. CHEST (analysis): Corner = 177 Hz, Slope = -15 dB/dec. The use of a single analog Butterworth filter with corner at 800 Hz and a slope of -30 dB/decade for anti-aliasing with sampling at 8000 Hz would preserve significant frequencies in both head and chest signals, and would allow further digital filtering using one of the recommended filters.			
17. Key Words Butterworth Filters Biomechanical Signal Processing System Parameter Identification Frequency Response		18. Distribution Statement Unlimited	
19. Security Classif. (of this report) None	20. Security Classif. (of this page) None	21. No. of Pages 191	22. Price

CONTENTS

	<u>Page</u>
List of Figures	v
List of Tables	vi
Summary	1
Introduction.....	2
Data Base	2
Spectral Analysis	3
Butterworth Filters	6
Impact Frequency Response	7
Grouping of Signals	8
Discussion and Recommendations	10
Filter Implementation.....	10
Appendices:	
A. Characterization of Frequency Response	26
B. Detailed Output of Characterization	64
C. Samples of Signals and Power Density Spectra	101

LIST OF FIGURES

	<u>Page</u>
1. Listing of BUTTER subroutine	13
2. Squared magnitude response of Butterworth filters	14
3. Magnitude response of Butterworth filters	15
4. Log magnitude responses of Butterworth filters	16
5. Traditional gain-frequency plots of filters	17
6. Characterization of power density spectrum	18
7. Recommended filter for HEAD signals.....	19
8. Recommended data acquisition filters for CHEST signals	20
9. Recommended data analysis filter for CHEST signals	21
10. Over-plot of recommended filters.....	22
11. Listing of FILTER subroutine to apply a Butterworth filter	23

LIST OF TABLES

	<u>Page</u>
1. Impact Tests Used in Filter Study.....	24
2. Frequency Response Summary (Non-Fracture).....	25
3. Frequency Response Summary (Fractures)	26

SUMMARY

Digital signals generated during head and chest impact tests were used as the basis for characterizing the frequency response of the human head and chest and to specify filters to be used during the data acquisition and analyses phases in biomechanical impact tests. About 450 signals were used in this *filter study*. These were combined into 35 different groups to produce different frequency response characterizations.

The grouping was based on several considerations. Those included whether the signal resulted from a head or a chest impact, the type of impacting surface, the direction of impact, the proximity of the sensor to the impact site, and whether a fracture occurred at or near the transducer mount. The sensitive axis of the sensor and the severity of impact were not considered as key factors in the grouping. No fractures occurred in only 23 groups, and these groups were eventually combined to produce the specifications for head and chest filters.

A low-pass Butterworth filter, specified by its -3 dB corner frequency (Hertz) and its rolloff slope (dB/decade), was used as a model to describe the frequency responses of the analyzed signals. An approximation procedure was developed and applied to estimate these two system parameters, given the limited information about the signals available for analysis.

Analysis of frequency responses of head signals indicated that a single filter may be used for data acquisition and/or analysis. For chest signals, it was not possible to specify a single filter. Instead, the analysis indicated that anti-alias filtering for data acquisition should use one filter, and filtering for biomechanical data analyses may use a lower-frequency filter. The three recommended Butterworth filters are:

	Corner (Hertz)	Rolloff (dB/dec)
HEAD	550	-26
CHEST (anti-alias)	500	-27
CHEST (analysis)	177	-15

It was also concluded that a single analog Butterworth filter with a corner at 800 Hz and a rolloff slope of -30 dB/decade may be used as an anti-alias filter for both head and chest signals with a sampling rate not below 8000 Hz, provided that signals are filtered further using the recommended filters.

INTRODUCTION

As part of the biomechanical data analysis task of the AATD program, a comprehensive filter study was undertaken to provide a rational basis for filtering biomechanical signals prior to their analysis and their use for specifying response characteristics of an advanced anthropomorphic test device.

The filter study used the biomechanical data base that was consolidated from various sources and experiments conducted over the past ten years. The objectives of this study were:

- A. To conduct a spectral analysis on all appropriate biomechanical signals in order to document their frequency contents.
- B. To use the spectral analysis to characterize the mechanical systems that produced them.
- C. Based on this characterization, to recommend specifications of the filters to be applied prior to analyzing biomechanical signals, and to extend these recommendations to the data acquisition instruments used during biomechanical testing.

The purpose of this document is to describe the methodology followed in the *filter study*, the rationales and justifications for their adoption, and the results and recommendations of the study.

DATA BASE

The complete data base that was available for the filter study consisted of over 5000 signals, not all of which were of practical use. After careful examination of these signals, only about 450 of them were finally selected as a basis for the study. There were several reasons for eliminating many signals from consideration, and for setting criteria for inclusion of others in the subset of the data base.

First of all, many signals contained in the complete data base do not pertain to biomechanical response *per se*, but are time-base, velocity, and other event-timing signals. Along with these signals were those that are "external" to the surrogate being tested, such as sled pulses, vehicle acceleration, and externally measured impactor accelerations and forces. This class of signals would (and should) not be used for characterization of the frequency response of human surrogates in biomechanical tests.

Second, a large number of signals were measured as responses of anthropomorphic dummies. Accelerometers and other transducers mounted on dummies provide response of the mechanical hardware of the dummy, and not of the skeletal or muscular structure of cadavers. Since the objective of this study

was to characterize human frequency response, and not that of a mechanical dummy, all signals generated from transducers mounted on dummies were eliminated from consideration for the filter study. This left only those signals generated in cadaver tests, from transducers (primarily accelerometers) mounted on cadavers.

A third reason for eliminating further cadaver signals was the low sampling rate of a large number of them. An objective study of frequency response should not be limited to low-frequency ranges, since many "events" could be happening near the higher end of the frequency spectrum. The NHTSA Biomechanics Data tape format requires that all signals be filtered at SAE Channel Class 1000, that has a corner frequency at 1650 Hz. Since the theoretical sampling rate which would preserve this frequency must be greater than twice the highest frequency in the signal, all signals that were sampled at rates less than 3200 Hz were eliminated from consideration in the filter study.

The resulting "pool" of acceptable tests was reduced to the 60 tests listed in Table 1. Signals from these tests had been digitized at different sampling rates that were chosen by the organizations who conducted the tests and/or digitized the analog signals. The majority of these were sampled at 6400 Hz, others at 8000, 10000, and 13333 Hz, and some at 25000 Hz.

Finally, signals that met all of the above criteria were further examined to determine their "quality," and to eliminate those that clearly did not represent cadaver response. These "rejects" were primarily "dead channels" and "broken cables," as indicated in the data base coding or determined from visual examinations. The remaining signals were assumed to be accurate and reliable responses of the tested cadavers at the indicated attachment sites.

SPECTRAL ANALYSIS

The following discussion is not intended to be a rigorous presentation, but is included here in order to define the terminology used in the study. For a complete presentation, the reader is referred to the textbook by A. V. Oppenheim and R. W. Shafer, *Digital Signal Processing*, Prentice-Hall, Inc., Englewood Cliffs, N.J., 1975.

A time signal $x(t)$ may be represented in the time domain as a finite sequence of N samples taken at a constant sampling rate, S , usually expressed in Hertz or samples per second. By assuming that this finite record represents one cycle in a periodic phenomenon, it is possible to express $x(t)$ in terms of a Fourier series consisting of a sum of sine and cosine terms at frequencies that are integer multiples of the fundamental frequency S/N associated with the periodic phenomenon:

$$x(t) = \sum_{k=0}^{N/2} A_k \cos [k(S/N)t] + B_k \sin [k(S/N)t]$$

This is known as the discrete Fourier series of the signal. The coefficients A_k and B_k may efficiently be computed using Fast Fourier Transform (FFT) algorithms.

Since both sine and cosine terms are at the same frequency, another form of the same equation is:

$$x(t) = \sum_{k=0}^{N/2} M_k \sin [k(S/N)t + \phi_k]$$

where $M_k^2 = A_k^2 + B_k^2$, and $\phi_k = \arctan (B_k/A_k)$.

The term M_k is the magnitude of the k -th frequency component, and ϕ_k is its phase angle. Both magnitude and phase may be plotted against frequency, and study of these responses is generally referred to as *spectral analysis*. Because the power of a signal is proportional to the square of its magnitude, sometimes the squared magnitude is plotted against the frequency. And depending on the units chosen for expressing this squared function, it is possible to consider its plot as the power function, usually referred to as the *power spectral density*, or PSD for short.

The discrete Fourier series states that any finite segment of a time signal is composed of pure sinusoidal components at frequencies ranging from zero (the D.C. term) up to the Nyquist frequency, which equals half the sampling rate. The number of components is limited to $N/2$, half of the number of time samples. This is a direct result of the *Sampling Theorem*. Another result is that frequencies above the Nyquist rate will be *folded* about this frequency and will *appear* in the digital signal as lower-frequency components that do not, in reality, exist in the analog signal. Since these *aliased* frequencies cannot be distinguished from *real* ones in the digital signal, it is necessary to filter out all components above the Nyquist frequency prior to digitizing, using low-pass filters. These filters are referred to as *anti-aliasing* filters.

While the phase response of a system is just as important as its magnitude response for its characterization, spectral analysis practices usually emphasize the study of the magnitude response. In this filter study, the focus will also be on the magnitude, since study of the phase requires more controlled data acquisition procedures than were documented in the available data base.

Most mechanical systems respond to external excitations by vibrations that can be monitored. When the excitation is a steady sinusoidal signal of a certain magnitude and phase angle, the system response is another sinusoidal motion at the same excitation frequency, but with a different magnitude and phase shift. When the excitation is impulsive, such as a short-lived impact, the response of the system appears to be random, and continues well after the excitation is removed,

and eventually dies out because of the damping that may exist in the system. It is from this type of excitation that most biomechanical signals are generated.

Frequency responses of most biomechanical systems, i.e., the plots of magnitude versus frequency, exhibit common features. Thus, there is always a D.C. term at zero frequency which, depending on the data acquisition equipment, may be the most prominent feature in the frequency spectrum. This occurs when the zero-bias in the signal amplifier is not removed. It could also occur when most of the signal lies on one side of the time axis, as in the case of contact forces. For most signals, however, this term is small and represents the mean of all the samples in the signal. Although the D.C. term is necessary for faithful reproduction of the original time signal, it may be ignored (i.e., assumed zero) for the purpose of characterizing the biomechanical system that generated the signal.

The response over the remainder of the spectrum, which extends to the Nyquist rate, typically decreases with frequency; that is, low-frequency components are more dominant than high-frequency ones. This behavior, characteristic of low-pass transfer functions, is typical of most mechanical systems, and may be explained in two ways.

Consider a signal that has been sampled at 8000 Hz. Spectral analysis of this signal extends to the Nyquist rate of 4000 Hz. Assume that, prior to digitizing, an SAE Channel Class 1000 was used as an anti-alias filter. Such a filter has a cutoff frequency of 1000 Hz and a corner of 1650 Hz. Because of the use of this anti-alias filter, all frequencies above the cutoff point of 1000 Hz have been gradually attenuated. Therefore, when examining the spectrum between 1000 and 4000 Hz, which *will* necessarily exhibit a "roll-off," it is not immediately obvious whether this attenuation is a characteristic of the mechanical system or is due to the anti-alias filter.

Assuming that the low-pass, anti-aliasing filter has a "flat" response up to its cutoff frequency, then any roll-off that is observed below this frequency may confidently be attributed to the mechanical system being measured. Of course, this further assumes that the instrumentation (transducers, conditioners, recorders, digitizers) does not alter the true response of the signal being monitored. It is this explanation that will enable us to characterize the biomechanical systems under consideration.

The approach taken in this study was simple but effective. Since most signals in the data base exhibited (as expected) a "low-pass" system behavior, a simple low-pass filter was used as a model to characterize specific groups of signals generated at various body parts. Because of the availability of the data, only responses of the head and chest were considered. The limitation imposed by the use of Channel Class 1000 as an anti-alias filter did not hinder the overall characterization, since most signals exhibited their roll-off behavior inside the useful range below 1000 Hz.

BUTTERWORTH FILTERS

One of the simplest low-pass filters that may be adopted as a model is the Butterworth filter, whose squared magnitude response function is given by:

$$|G(\omega)|^2 = 1 / [1 + (\omega/\omega_c)^{2n}]$$

where $G(\omega)$ is the filter's gain as a function of frequency, ω_c is the corner frequency, and n is the order of the filter. The appeal of the Butterworth filter lies in the simplicity and flexibility of its definition and digital simulation, as well as in its properties. The most distinctive property of these filters is that they are *maximally flat* in the passband. This and other properties are explored in the following paragraphs.

A simple computer program to simulate the frequency response of a Butterworth filter is listed in Figure 1. The filter is specified by its corner and rolloff slope from which its order may be derived. The number of samples and sampling rate are used only as a guideline to define the number of frequencies at which the filter gain is computed, as well as the interval between adjacent frequencies. In the version listed in Figure 1, the returned GAIN was set equal to the squared magnitude, SMAG, but could easily be modified to return the magnitude itself, GMAG, or its value in deciBels, DBEL. This is precisely what was done to generate the frequency responses shown in Figures 2, 3, and 4. Typically, however, the frequency response is displayed, as shown in Figure 5, on a semi-logarithmic paper, where the gain (deciBels) is plotted along the vertical linear axis, against the frequency (Hertz) along the horizontal logarithmic axis.

It is clear that, as the order of the Butterworth filter increases, its characteristics become sharper but the gain at the corner frequency remains the same. Because the power of a sinusoidal signal is proportional to its squared magnitude, and since the square magnitude function at the corner is equal to one-half regardless of the order, the corner frequency is usually referred to as the *half-power* point of the filter, where the gain is -3dB. In other words, frequencies passed by the filter that are below the corner will retain at least half of their power, while those that are above the corner will lose at least half of their power.

Another important property of Butterworth filters, which may be observed in Figure 5, is that the frequency response in the rolloff region is asymptotic to a straight line when the frequency is plotted along a logarithmic axis. The straight-line asymptote always intercepts the 0-dB line at the corner frequency, but its slope (in dB/decade or dB/octave) is proportional to the order n of the filter. Thus, the slope is -20 dB/decade for $n=1$, -40 dB/decade for $n=2$, and so on.

Unless the Butterworth filter is intended for analog implementation, there is no reason to restrict the order n to an integer. Thus, a rolloff slope of -50 dB/decade may be achieved by specifying $n=2.5$ for the order. This provides an appealing flexibility in the digital simulation of the Butterworth filter, especially

when it is used as a model for unknown frequency responses. Consequently, it is more appropriate (as was done in the coding of BUTTER program, Figure 1) to specify the filter by its corner frequency and its rolloff slope, which may not necessarily be an integer multiple of 20 dB/decade. The parameter n , required for computing $G(\omega)$, is then simply derived from the specified slope as the ratio of slope over the 1st-order slope of 20 dB/decade.

Finally, since the asymptote always intercepts the 0-dB line at the corner frequency, a quick sketch of the actual response of the filter is possible, without elaborate computations, given only the corner and slope. Note, however, that the vertical separation between the actual curve and the asymptote, for frequencies above the corner, cannot exceed 3 dB, with the largest deviation (3 dB) always occurring at the corner, and decreasing as the frequency increases.

These properties allow the identification of the two filter parameters, given an experimentally measured frequency response curve of the filter. To do this, one would locate on the actual curve the frequency where the gain crosses the -3 dB level. This is the corner frequency of the filter, which also identifies the 0-dB intercept point of the asymptote. By drawing a straight line that passes through this point asymptotically to the rolloff portion of the given curve, the slope and, consequently, the order of the filter may be determined. This graphic identification procedure was the basis for the algorithm that was developed and used in the filter study.

IMPACT FREQUENCY RESPONSE

A linear and stable system being excited with a random white noise produces a response. Under some conditions, the squared magnitude response may be considered an adequate approximation of the power density spectrum (PDS), especially when the PDS is smooth and approaches zero at finite frequencies. Since the biomechanical signals were produced from an impulsive (non-white) input, the resulting PDS is "noisy" and must be smoothed prior to any further analysis. Therefore, approximation techniques were developed in this study to characterize the frequency response of the impact signals and to identify the parameters of the biomechanical systems in question.

The PDS of a typical biomechanical impact signal generally exhibits a roll-off characteristic at high frequencies and a noisy response over the entire spectrum. It is more convenient to base the system identification procedure on a smoother distribution derived from the experimentally generated PDS curve. Such a smooth distribution is the integral of the PDS, which may be shown to be also proportional to the power content in the signal over the frequency interval of integration.

The approximation procedure followed in this study may be illustrated by applying it to a well-understood system. Thus, consider the already-smooth PDS of a Butterworth filter whose corner is 500 Hz and rolloff is -20 dB/decade. The

PDS of this (500/-20) filter is shown in Figure 6 along with its cumulative PDS function. The frequencies of five landmarks on the cumulative PDS are then identified to serve as the basis for estimating the corner and rolloff slope of a low-pass system. These landmarks correspond to the 50, 75, 90, 95, and 99% levels of the cumulative PDS, which may be considered, for the purpose of approximation, as the 50, 25, 10, 5, and 1% respective power points in the low-pass system. In terms of deciBels, these translate into -3, -6, -10, -13, and -20 dB gains of the desired characterization.

Once these five landmarks have been identified, they may be used in an algorithm that corrects for deviations from a hypothetical asymptote (as discussed earlier) to produce approximate points on the asymptote. These corrected points are then fitted to a straight line whose intersection with the 0-dB line is the corner, and slope is the rolloff of the approximated low-pass Butterworth characterization. For the (500/-20) filter, this produced the approximation (549/-21) that is shown in Figure 6 as the dashed curve. Of course, for actual signals, the approximation may not be as close to the unknown characteristics as shown in the example, depending on the smoothness of the PDS curve, and on the order (rolloff) of the unknown system. However, given the information available for this study, it was felt that this procedure is adequate if care is exercised in interpreting the results.

This simple system parameter identification procedure may be repeated for several signals that were produced under similar test conditions of the same mechanical system. Then the resulting corners and rolloffs are averaged to obtain better estimates of the system parameters. Alternatively, the five landmarks obtained from different signals may be averaged first. Then an approximate filter may be derived from the five averaged landmarks. In this study, the 450 signals were first analyzed to extract the five landmarks, combined into 35 different groups of compatible signals, then averaged to produce 35 different sets of five landmarks.

Because of statistical variations of the landmark frequencies in each group, and since the resulting characterization was intended to preserve significant frequency components in current and future biomechanical signals, the straight-line fitting procedure was applied, not to the average landmark frequencies, but to frequencies that were *one standard deviation above the average*. This ensured that significant frequencies which were present in the signals would fall in the passband, and allowed for uncertainties and errors during the data acquisition and analysis phases of the signals. The resulting 35 low-pass filter characterizations are, therefore, *conservative estimates* that are not likely to filter out significant frequencies.

GROUPING OF SIGNALS

The system parameter identification procedure outlined in the previous sections was applied to the appropriate signals available in the data base. First,

the selected signals were grouped by test type, restraint conditions and/or impact surface, and by transducer attachment location. A list of the sixty (60) tests from which these signals were obtained is given in Table 1. The results of the analysis of 35 groups of signals are presented in Appendices A and B, and are summarized in Tables 2 and 3.

In combining the available signals in the 35 groups, several factors were taken into account. First, the head and chest signals were separated to produce characterization of two physically separate body parts. Another consideration was the type of impact surface that produced the response. This is defined by the restraint system that was in contact with the chest during the tests, or by the padding, if any, that was added to the impactor in head and chest pendulum impacts. The velocity of impact, which affects the magnitude of the response but not its frequency content, was not considered as a factor in grouping the various signals. Similarly, the direction of the sensitive axis of the transducer was ignored in the grouping, since the vibration of the sensor reflects the underlying bony structure and would contain the same frequency information regardless of the sensing direction.

The third consideration was the proximity of the transducer mounting location to the impact site. It may be argued that, as the sensor is located farther away from the impact site, the response is attenuated but its frequency content should remain unchanged. While this may be true for a rigid or nearly-rigid body such as the head, the thorax is much more complicated and contains structures that may respond differently. Therefore, the chest signals were grouped by whether they were near the impact site, at the far and opposite side of the chest, or at mid-range between these two extremes. This necessitated dividing the tests into lateral (left-side) and frontal impacts, then grouping the signals as follows:

	Near Side	Mid Range	Far Side
LATERAL	LLR, LUR	LST, UST T01, T12	RLR, RUR
FRONTAL	LST, UST	LLR, LUR RLR, RUR	T01, T12

The last factor that was taken into account was whether a bone fracture occurred at or near the transducer mount. This is an important consideration because, when the integrity of the bony structure is violated by a fracture, the response of the system becomes erratic and can no longer be attributed solely to the structural vibration of the biomechanical system. These groups are included in the results to demonstrate the frequency characteristics of fractured systems, but should not (and were not) used to draw conclusions about the chest or head frequency response.

This grouping scheme resulted in 35 separate characterizations of the available signals, of which 12 groups were ignored because they consisted of signals where fractures occurred. The remaining 23 "filters" are listed in Table 2 and

are presented as six chest groups and one head group. The weighted logarithmic average of the corner frequencies in each group, as well as the weighted arithmetic average of the rolloff slopes, are also given. Those "filters" marked with an asterisk (*) were not included in the averaging because they were clearly low extremes and because their omission would not adversely affect the intended goal of preserving the high frequency components in signals. The averaging process reduced the number of filters to six for the chest, and one for the head. The average corners and slopes are shown in Table 2, in parenthesis, at the bottom of each group.

DISCUSSION AND RECOMMENDATIONS

An examination of the six Butterworth filter characterization of chest frequency response reveals that five of them are clustered near the (200/-15) filter, while one is near (500/-25) filter. Further reduction of the number of chest filters is obtained by an additional weighted averaging of the five-filter cluster to produce the (177/-15) filter. Note that the 177 Hz is a corner frequency at which the filter gain is -3 dB, and should not be confused with the SAE J211 Channel Class 180, which has its corner frequency at 300 Hz. Note also that, in obtaining the (177/-15) average, only five filters were used and did not include the (493/-27) filter. Even when this filter is included in the averaging, the result is a (186/-16) six-filter average that is not much higher than the five-filter average.

It is tempting to specify the overall average of (186/-16) as a do-it-all filter to be used during the data acquisition and analyses phases of all thoracic signals. It is more prudent, however, to allow for uncertainties in these phases and specify a filter that would preserve the highest frequency which may occur, without imposing unrealistic and unfounded restrictions. Therefore, the (500/-27) filter, i.e., the Butterworth filter whose corner frequency is 500 Hertz and whose rolloff slope is -27 dB/decade, should be used during the instrumentation and data acquisition phases of biomechanical testing of the thorax. Once the data have been digitized, additional filtering using the (180/-15) filter may be applied to the thoracic signals when warranted. For head signals, a (550/-26) filter, which is almost identical to the one specified for chest signals, should be used during both the data acquisition and analyses phases. The frequency responses of these filters are given in Figures 7, 8, and 9. For convenience, these are overplotted in Figure 10.

FILTER IMPLEMENTATION

The two head and chest filters recommended for anti-aliasing during data acquisition are almost identical with corner frequencies near 500 Hz and rolloff slopes near -27 dB/decade. While such a filter may easily be realized in a digital simulation, it cannot be designed as an analog Butterworth filter since its order (27/20 or 1.35) requires 2.7 poles in the realization. The nearest analog filter that would have 3 poles for a rolloff slope of -30 dB/decade. If the (800/-30) filter were used as anti-alias filter, and if the sampling rate were 8000 Hz, as recom-

mended in the SAE J211 instrumentation guideline, then the gain of frequencies above the Nyquist rate of 4000 Hz would be no higher than -20 dB, an adequate anti-aliasing attenuation. Higher sampling rates would, of course, produce additional anti-aliasing attenuation when the (500/-30) filter is used.

Digital implementation of any Butterworth filter is simple but requires that the filtering be done in the frequency domain. A Fast Fourier Transform (FFT) algorithm must therefore be available, in hardware or software, before filtering can be done. Using the FFT, the frequency spectrum of the time signal is first obtained. The gain of the desired filter is then computed at every frequency in the spectrum, then multiplied by the magnitude of corresponding signal component. The inverse FFT is then applied to the modified signal component to return to the time domain.

A listing of the Fortran subroutine FILTER is given in Figure 11. The program requires an algorithm (FFT) that performs the direct and inverse Fourier transforms. Input to this routine are the time signal (SIG) to be filtered, the number of samples (NPT), the sampling rate (SHZ), as well as the corner (CORN) and rolloff (ROLL) of the desired filter. The gain of the Butterworth filter is computed as filtering is performed. The routine returns, in the SIG array, the filtered time signal. Note that, in this simple implementation, the phase response is not applied to the signal but may, in a more sophisticated implementation, be applied by modifying differently the sine and cosine terms of the Fourier series. Other implementations may include a section where the signal is extended at either end to eliminate possible distortions, then "return" only the original time segment.

```

SUBROUTINE BUTTER (NPT,SHZ, CORN,ROLL, GAIN,NFRQ)

C      Frequency response of a Butterworth filter

C      Input:      NPT  ... Number of samples in signal
C                  SHZ  ... Sampling rate (Hertz)
C                  CORN ... Corner frequency (Hertz)
C                  ROLL ... Roll-off slope (dB/decade)

C      Output:     GAIN ... Magnitude response of filter
C                  NFRQ ... Number of frequencies

REAL*4 GAIN(1)

FUNHZ = SHZ / NPT
ORDER = ABS( ROLL / 20 )
POWER = 2 * ORDER
WFUND = FUNHZ / CORN
NHALF = NPT / 2
NFRQ = NHALF + 1

DO 10 K = 1, NFRQ

    W = (K-1) * WFUND
    DENOM = 1. + W ** POWER
    SMAG = 1. / DENOM
    GMAG = SQRT( SMAG )
    DBEL = 20. * ALOG10( GMAG )
    GAIN(K) = SMAG
C      GAIN(K) = GMAG
C      GAIN(K) = DBEL

10    CONTINUE

RETURN
END

```

Figure 1 - Listing of BUTTER subroutine to compute filter gain.




Figure 2 - Square magnitude responses of Butterworth filters.




Figure 3 - Magnitude responses of Butterworth filters.




Figure 4 - Log magnitude responses of Butterworth filters.




Figure 5 - Traditional gain-frequency plots of filters.




Figure 6 - Characterization of the power density spectrum.

Recommended Filter for HEAD Signals




Figure 7 - Recommended filter for HEAD signals.

Recommended Filter for CHEST Signals
(for Data Acquisition)




Figure 8 - Recommended data acquisition filter for CHEST signals.

Recommended Filter for CHEST Signals (for Data Analysis)




Figure 9 - Recommended data analysis filter for CHEST signals

SUMMARY OF FILTERS




Figure 10 - Summary of recommended filters.

```

SUBROUTINE FILTER ( SIG, NPT, SHZ, CORN, ROLL )

C   Purpose:   Apply a Butterworth filter to signal.

C   SIG   ... Time signal before/after filtering
C   NPT   ... Number of points (samples) in signal
C   SHZ   ... Sampling rate of signal, (Hertz)

C   CORN  ... -3dB corner of desired filter, (Hertz)
C   ROLL  ... Rolloff slope of filter, (dB/decade)

REAL*4 SIG(1)

FUNHZ = SHZ / NPT
WFUND = FUNHZ / CORN

ORDER = ABS ( ROLL / 20 )
POWER = 2 * ORDER

NFREQ = NPT / 2

C   Transform signal to frequency domain

CALL FFT ( NPT, SIG, +1 )

C   Compute filter gain, then apply to signal

DO 100 K = 1, NFREQ

    IB = 2 * K
    IA = IB - 1

    W = ( K-1 ) * WFUND
    GINV = 1 + W ** POWER
    GAIN = 1 / SQRT ( GINV )

    SIG ( IA ) = GAIN * SIG ( IA )
    SIG ( IB ) = GAIN * SIG ( IB )

100 CONTINUE

C   Transform signal back to time domain

CALL FFT ( NPT, SIG, -1 )

RETURN
END

```

Figure 11 - Listing of FILTER subroutine to apply a Butterworth filter.

Table 1 - Pool of Impact Tests Used in Filter Study

Tape No.	File No.	Signals	Test ID	Test: Type	Direction	Restraint	Subject: Age	Height	Weight	Performer	Test Date	Test Description
2.1021	28		82-04	OCC	999	3PT	40	62	132	HDL	01/13/82	FAT PROGRAM
2.1050	28		82-05	OCC	999	3PT	43	70	170	HDL	12/03/82	FAT PROGRAM
1.2154	20		A-877	SLD	0	3PT	76	59	88	HSR	06/20/75	EA COLUMN,LAP BELT PROD.
1.2175	20		A-880	SLD	0	3PT	74	67	106	HSR	06/27/75	EA COLUMN,LAP BELT PROD.
1.2214	18		A-883	SLD	0	LAP	74	61	166	HSR	07/07/75	EA COLUMN,LAP BELT PROD.
1.2233	19		A-884	SLD	0	LAP	60	70	198	HSR	07/10/75	EA COLMN,PAD INSRT&LAP BEL
1.2253	18		A-887	SLD	0	ABG	68	68	188	HSR	07/22/75	EA COL,AIRBAG INSRT,LAP BL
1.2272	22		A-923	SLD	0	ABG	69	65	81	HSR	09/17/75	EA COL,AIRBAG INSRT,LAP BL
1.2295	21		A-924	SLD	0	ABG	64	67	168	HSR	10/01/75	EA COL,AIRBAG INSRT,LAP BL
2.0570	24		A-925	SLD	999	3PT	99	70	171	HSR	09/26/75	WBR-7
2.0595	24		A-926	SLD	999	3PT	99	70	171	HSR	09/26/75	WBR-7
1.2317	20		A-927	SLD	0	ABG	72	64	177	HSR	10/08/75	EA COL,AIRBAG INSRT,LAP BL
1.2338	20		A-928	SLD	0	LAP	50	64	125	HSR	10/09/75	EA COL,SOFT INSRT,LAP BL
2.0620	24		A-934	SLD	999	3PT	99	68	132	HSR	11/14/75	WBR-8
1.2359	20		A-937	SLD	0	LAP	48	64	148	HSR	12/11/75	EA COL,SOFT INSRT,LAP BL
2.0694	23		A-938	SLD	999	3PT	99	68	137	HSR	12/15/75	WBR-9
2.0001	10		MS 91	OTH	13	999	69	99	999	APR	07/16/76	FACE DROP
2.0012	10		MS 92	OTH	0	999	69	99	999	APR	07/19/76	FACE DROP
1.3410	12		75A113	CAN	90	999	54	70	183	HSR	11/08/75	M PAD AIS=4
1.3423	12		75A116	CAN	90	999	66	59	97	HSR	12/10/75	F PAD AIS=0
1.3436	12		76A126	CAN	0	999	65	71	179	HSR	02/27/76	M PAD AIS=4
1.3449	11		76A133	CAN	0	999	54	69	179	HSR	03/03/76	M PAD AIS=3
1.3461	11		76A134	CAN	90	999	72	67	104	HSR	03/12/76	F PAD AIS=2
1.3473	11		76A135	CAN	180	999	68	63	140	HSR	03/17/76	F PAD AIS=0
1.3485	12		76A136	CAN	0	999	88	67	168	HSR	03/27/76	M PAD AIS=3
1.3510	12		76A144	CAN	0	999	45	66	166	HSR	04/29/76	M RIG AIS=2
1.3523	12		76A145	CAN	90	999	78	63	177	HSR	05/06/76	F RIG AIS=5
1.3536	12		76A152	CAN	90	999	66	63	99	HSR	05/11/76	F RIG AIS=5
2.0718	23		76B001	SLD	999	3PT	99	69	138	HSR	12/13/76	WBR-10
1.2380	17		76T003	SLD	270	RIG	60	71	225	HSR	01/27/76	LAT IMPACT RIG SURF
1.2398	25		76T008	SLD	0	3PT	74	64	156	HSR	03/25/76	3PT INFLAT.BELT,FRNT SLED
1.2424	20		76T009	SLD	270	RIG	75	61	97	HSR	04/06/76	LAT IMPACT RIG SURF
1.2445	20		76T010	SLD	270	RIG	84	63	193	HSR	04/15/76	LAT IMPACT RIG SURF
1.2466	20		76T011	SLD	270	RIG	69	67	165	HSR	04/23/76	LAT IMPACT RIG SURF
1.2487	25		76T020	SLD	0	ABG	78	62	140	HSR	06/03/76	FRNT SLED,EA COLMN,AIRBAG
1.2513	11		76T021	CAN	0	NON	55	63	95	HSR	06/14/76	THORACIC IMPACT,CANNON
1.2525	11		76T022	CAN	0	NON	85	64	132	HSR	06/22/76	THORACIC IMPACT,CANNON
1.2537	11		76T024	CAN	0	NON	75	66	167	HSR	06/25/76	THORACIC IMPACT,CANNON
1.2549	11		76T025	CAN	0	NON	66	68	153	HSR	06/30/76	THORACIC IMPACT,CANNON
1.2561	16		76T029	SLD	270	MCI	67	65	137	HSR	07/28/76	SLED,SIDE DOOR IMPCT
1.2578	18		76T034	SLD	270	MCI	62	72	130	HSR	08/12/76	SLED,SIDE DOOR IMPACT
1.2597	17		76T039	SLD	270	MCI	72	73	162	HSR	08/19/76	SLED,SIDE DOOR IMPACT
1.2196	17		76T042	SLD	270	MCI	58	70	142	HSR	08/23/76	SLED,SIDE DOOR IMPACT
1.2615	12		76T050	PEN	0	NON	61	69	184	HSR	10/28/76	PENDULUM,14FT/SEC FRNT IMP
1.2628	15		76T053	PEN	0	NON	63	68	231	HSR	11/11/76	PENDULUM 14FT/SEC FRNT IMP
1.2644	16		76T056	PEN	0	NON	40	99	154	HSR	12/03/76	PENDULUM 14FT/SEC FRNT IMP
1.2661	15		76T059	PEN	0	NON	76	99	194	HSR	12/07/76	PENDULUM 14FT/SEC FRNT IMP
1.2677	15		76T062	PEN	270	NON	69	68	110	HSR	12/16/76	PENDULUM 14FT/SEC SIDE IMP
1.2693	15		76T065	PEN	270	NON	63	99	209	HSR	12/21/76	PENDULUM 14FT/SEC SIDE IMP
1.2709	16		77T068	PEN	0	NON	52	68	136	HSR	07/08/77	PENDULUM 14.33FT/S FRNT IMP
1.2726	16		77T071	PEN	270	NON	60	67	176	HSR	07/13/77	PENDULUM 14.3FT/S SIDE IMP
1.2743	16		77T074	PEN	270	NON	60	69	119	HSR	07/18/77	PENDULUM 14.32FT/S SIDE IMP
1.2760	16		77T077	PEN	270	NON	79	69	162	HSR	07/22/77	PENDULUM 19.9FT/S SIDE IMP
1.2777	16		77T080	PEN	270	NON	64	67	89	HSR	08/10/77	PENDULUM 20FT/S SIDE IMP
1.2794	17		77T083	PEN	0	NON	60	61	140	HSR	08/30/77	PENDULUM 20FT/S FRNT IMP
1.2812	16		77T086	PEN	0	NON	54	64	172	HSR	09/08/77	PENDULUM 20FT/S FRNT IMP
1.2829	18		77T089	SLD	270	RIG	66	68	121	HSR	09/19/77	SLED RIG WALL SIDE IMP
1.2848	18		77T092	SLD	270	RIG	45	69	128	HSR	09/28/77	SLED RIG WALL SIDE IMP
1.2867	18		77T095	SLD	270	MCI	77	72	204	HSR	10/11/77	SLED PADDED WALL(REPORT)
1.2886	18		77T098	SLD	270	MCI	71	66	130	HSR	10/27/77	SLED PADDED WALL(REPORT)

Table 2 - Summary of Butterworth Characterization: Non-Fracture Signals

Filter Number	Corner (Hz)	Slope (dB/dec)	Sensors	Locations	Test Types
LP01	641.	-33.7	3	LLR	SLD/MCI
LP05	510.	-23.1	4	LLR	SLD/RIG
LP09	422.	-26.1	6	LUR LLR	PEN/L-R
Avg. =	(493. /	-26.9)		(Near-side)	(Lateral)
LP11	200.	-13.6	34	UST LST T01 T12	SLD/MCI
LP12	208.	-16.9	39	UST LST T01 T12	SLD/RIG
LP13	106.	-13.4	44	UST LST T01 T12	PEN/L-R
Avg. =	(160. /	-14.6)		(Mid-range)	(Lateral)
LP02	151.	-15.0	6	RUR RLR	SLD/MCI
LP06	257.	-17.7	9	RUR RLR	SLD/RIG
LP10 *	62.	-9.6	12	RUR RLR	PEN/L-R
Avg. =	(208. /	-16.6)		(Far-side)	(Lateral)
LP16 *	15.	-8.6	9	UST LST	SLD/ABG
LP22	155.	-15.1	8	UST LST	SLD/LAP
LP28	158.	-15.7	11	UST LST	PEN/A-P
Avg. =	(157. /	-15.4)		(Near-side)	(Frontal)
LP14	143.	-13.6	18	LUR LLR RUR RLR	SLD/ABG
LP18 *	21.	-6.6	2	LUR LLR	SLD/3PT
LP21	271.	-16.2	23	LUR LLR RUR RLR	SLD/LAP
LP26	492.	-26.9	6	LUR LLR RUR RLR	PEN/A-P
Avg. =	(229. /	-16.6)		(Mid-range)	(Frontal)
LP17	159.	-16.2	20	T01 T12	SLD/ABG
LP20 *	23.	-7.5	4	T01 T12	SLD/3PT
LP24	172.	-14.7	20	T01 T12	SLD/LAP
LP30	234.	-14.3	13	T01 T12	PEN/A-P
Avg. =	(180. /	-15.2)		(Far-side)	(Frontal)
LP33	547.	-25.7	33	HD1 HD2 HD3 HED	DIR NOPAD
LP34 *	49.	-11.8	18	HD1 HD2 HD3 HED	DIR W/PAD
LP35 *	17.	-14.1	15	HD1 HD2 HD3 HED	NO DIRECT IMPACT
Avg. =	(547. /	-25.7)			

Table 3 - Frequency Response of Signals Where Fractures Occurred


Filter Number	Corner (Hz)	Slope (dB/dec)	Sensors	Locations	Test Types
LP03	611.	-30.4	7	LUR LLR	SLD/MCI
LP04	212.	-13.6	4	RUR RLR	SLD/MCI
LP07	496.	-25.1	8	LUR LLR	SLD/RIG
LP08	658.	-31.0	3	RUR RLR	SLD/RIG
LP15	1012.	-46.6	2	RUR LUR	SLD/ABG
LP19	316.	-23.1	2	RUR RLR	SLD/3PT
LP23	74.	-8.7	3	UST	SLD/LAP
LP25	60.	-11.6	2	T01	SLD/LAP
LP27	658.	-31.4	2	RUR	PEN/A-P
LP29	65.	-14.2	3	LST UST	PEN/A-P
LP31	1303.	-19.9	28	HED HD1 HD2 HD3	DIR NOPAD
LP32	85.	-11.7	10	HD1 HD2 HD3 HED	DIR W/PAD

Appendix A


CHARACTERIZATION OF FREQUENCY RESPONSE

In this Appendix, the 35 low-pass Butterworth filter characterization of biomechanical signals from chest and head accelerometers are presented in graphical form. The information displayed on each figure documents the source of the signals, their group type and location, and the resulting system parameters. These are identified by boxed numbers on the LEGEND given on the next page.

- (1) Filter designation in this series, LP01 through LP35.
- (2) Test conditions and type codes:
 - SLD ... Sled tests
 - PEN ... Pendulum and/or Cannon tests
 - DIR ... Direct head impacts
 - NO DIR ... Indirect head impact tests
 - MCI ... Padded side impact
 - RIG ... Rigid side impact
 - ABG ... Airbag frontal impact
 - 3PT ... 3-Point restraint frontal test
 - LAP ... Lap belt only frontal impact
 - A-P ... Frontal pendulum/cannon impact
 - L-R ... Lateral pendulum/cannon impact
 - W/PAD ... Padded head impact
 - NOPAD ... Rigid head impact
 - FRAC ... Fracture at/near transducer location
 - NOFX ... No fracture at/near transducer
- (3) Transducer location:
 - LUR ... Left upper rib
 - LLR ... Left lower rib
 - RUR ... Right upper rib
 - RLR ... Right lower rib
 - UST ... Upper sternum
 - LST ... Lower sternum
 - T01 ... Spinal vertebra T1
 - ... Others: T06, T12, etc.
 - HED ... Head accelerometer
 - HD1 ... Head triax or biaxial number 1
 - HD2 ... Head triax or biaxial number 2
 - HD3 ... Head triax or biaxial number 3
- (4) Number of signals in the group
- (5) Corner frequency of resulting filter approximation
- (6) Rolloff slope of the resulting filter approximation
- (7) Average frequency of landmarks at a given PDS level
- (8) Average PLUS one standard deviation of landmarks
- (9) Landmark corrected for deviation from asymptote
- (10) Asymptote which best fits the 5 corrected landmarks
- (11) Frequency response curve of approximate filter





LP21 Tests: SLD/LAP NOFX [1] Sensors: LUR LLR RUR RLR [2] [3]




LP01 Tests: SLD/MCI NOFX

Sensors: LLR






LP03 Tests: SLD/MCI FRAC Sensors: LUR LLR




LP04 Tests: SLD/MCI FRAC Sensors: RUR RLR





LP05 Tests: SLD/RIG NOFX

Sensors: LLR




LP06 Tests: SLD/RIG NOFX Sensors: RUR RLR







LP08 Tests: SLD/RIG FRAC Sensors: RUR RLR




LP09 Tests: PEN/L-R NOFX Sensors: LUR LLR

LP09 Tests: PEN/L-R NOFX






LP11 Tests: SLD/MCI NOFX Sensors: UST LST T01 T12




LP12 Tests: SLD/RIG NOFX Sensors: UST LST T01 T12




LP13 Tests: PEN/L-R NOFX Sensors: UST LST T01 T12


LP14 Signals = 18 Corner = 143 Hz Roll = -13.6 dB/dec




LP14 Tests: SLD/ABG NOFX Sensors: LUR LLR RUR RLR




LP15 Tests: SLD/ABG FRAC Sensors: RUR LUR




LP16 Tests: SLD/ABG NOFX Sensors: UST LST




LP17 Tests: SLD/ABG NOFX Sensors: T01 T12





LP18 Tests: SLD/3PT NOFX Sensors: LUR LLR







LP20 Tests: SLD/3PT NOFX Sensors: T01 T12









LP23 Tests: SLD/LAP FRAC Sensors: UST




LP24 Tests: SLD/LAP NOFX Sensors: T01 T12








LP26 Tests: PEN/A-P NOFX Sensors: LUR LLR RUR RLR



LP27 Tests: PEN/A-P FRAC Sensors: RUR










LP30 Tests: PEN/A--P NOFX Sensors: T01 T12

LP31 Signals = 28 Corner = 1303 Hz Roll = -19.9 dB/dec




LP31 Tests: DIR NOPAD FRAC Sensors: HED HD1 HD2 HD3






LP33 Tests: DIR NOPAD NOFX Sensors: HD1 HD2 HD3 HED



LP34 Tests: DIR W/PAD NOFX Sensors: HD1 HD2 HD3 HED



LP35 Tests: NO DIRECT IMPACT Sensors: HD1 HD2 HD3 HED

Appendix B

DETAILED OUTPUT OF CHARACTERIZATION

This Appendix is included to present the entire data used for characterizing the frequency response of the signals, as well as the intermediate and final results of the analysis. These are presented in 35 separate pages corresponding to the 35 analyzed groups of signals.

SUMMARY OF CHARACTERIZATIONS

Filter Number	Corner (Hz)	Slope (dB/dec)	Sensors	Test Type
LP01	641.	-33.7	3 LLR	SLD/MCI NOFX
LP02	151.	-15.0	6 RUR RLR	SLD/MCI NOFX
LP03	611.	-30.4	7 LUR LLR	SLD/MCI FRAC
LP04	212.	-13.6	4 RUR RLR	SLD/MCI FRAC
LP05	510.	-23.1	4 LLR	SLD/RIG NOFX
LP06	257.	-17.7	9 RUR RLR	SLD/RIG NOFX
LP07	496.	-25.1	8 LUR LLR	SLD/RIG FRAC
LP08	658.	-31.0	3 RUR RLR	SLD/RIG FRAC
LP09	422.	-26.1	6 LUR LLR	PEN/L-R NOFX
LP10	62.	-9.6	12 RUR RLR	PEN/L-R NOFX
LP11	200.	-13.6	34 UST LST T01 T12	SLD/MCI NOFX
LP12	208.	-16.9	39 UST LST T01 T12	SLD/RIG NOFX
LP13	106.	-13.4	44 UST LST T01 T12	PEN/L-R NOFX
LP14	143.	-13.6	18 LUR LLR RUR RLR	SLD/ABG NOFX
LP15	1012.	-46.6	2 RUR LUR	SLD/ABG FRAC
LP16	15.	-8.6	9 UST LST	SLD/ABG NOFX
LP17	159.	-16.2	20 T01 T12	SLD/ABG NOFX
LP18	21.	-6.6	2 LUR LLR	SLD/3PT NOFX
LP19	316.	-23.1	2 RUR RLR	SLD/3PT FRAC
LP20	23.	-7.5	4 T01 T12	SLD/3PT NOFX
LP21	271.	-16.2	23 LUR LLR RUR RLR	SLD/LAP NOFX
LP22	155.	-15.1	8 UST LST	SLD/LAP NOFX
LP23	74.	-8.7	3 UST	SLD/LAP FRAC
LP24	172.	-14.7	20 T01 T12	SLD/LAP NOFX
LP25	60.	-11.6	2 T01	SLD/LAP FRAC
LP26	492.	-26.9	6 LUR LLR RUR RLR	PEN/A-P NOFX
LP27	658.	-31.4	2 RUR	PEN/A-P FRAC
LP28	158.	-15.7	11 UST LST	PEN/A-P NOFX
LP29	65.	-14.2	3 LST UST	PEN/A-P FRAC
LP30	234.	-14.3	13 T01 T12	PEN/A-P NOFX
LP31	1303.	-19.9	28 HED HD1 HD2 HD3	DIR NOPAD FRAC
LP32	85.	-11.7	10 HD1 HD2 HD3 HED	DIR W/PAD FRAC
LP33	547.	-25.7	33 HD1 HD2 HD3 HED	DIR NOPAD NOFX
LP34	49.	-11.8	18 HD1 HD2 HD3 HED	DIR W/PAD NOFX
LP35	17.	-14.1	15 HD1 HD2 HD3 HED	NO DIRECT IMPACT

Tests = SLD/MCI NOFX

Sensors = LLR

LP01

FILTER ESTIMATION

3 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	230	589	926	1114	1517
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	550	962	1353	1558	2031
641. -33.7 <-----	Adjusted Asymptote (Hz) =	788	967	1269	1559	2511
	Best-Fit Filter (Hz) =	641	888	1230	1535	2504

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>						
1-2563	02.	AC LLR X G'S	76T029	1792 6410	121	360	648	798	1033		
1-2599	02.	AC LLR X G'S	76T039	1760 6410	789	1149	1565	1764	2092		
1-2889	03.	AC LLR X G'S	77T098	1856 6410	128	495	784	981	1617		

Tests = SLD/MCI NOFX

Sensors = RUR RLR

LP02

FILTER ESTIMATION

6 Signals

SUMMARY OF SPECTRAL ANALYSIS

		Cumulative P.S.D. (%) =	50	75	90	95	99
		% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit		Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF		MEAN LOG Frequency (Hz) =	41	101	345	532	1385
(Hz)	(dB/dec)	MEAN+1SD Frequency (Hz) =	120	308	987	1273	1614
151.	-15.0 <----	Adjusted Asymptote (Hz) =	240	382	705	1119	3279
		Best-Fit Filter (Hz) =	151	315	657	1081	3257

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2566	05.	AC RUR Y G'S	76T029	1792 6410	9	19	53	100	1391
1-2602	05.	AC RUR Y G'S	76T039	1760 6410	72	362	1361	1551	1883
1-2565	04.	AC RLR X G'S	76T029	1792 6410	58	81	200	358	1279
1-2582	04.	AC RLR X G'S	76T034	1522 6410	257	454	574	700	1307
1-2601	04.	AC RLR X G'S	76T039	1760 6410	20	97	756	984	1407
1-2872	05.	AC RLR X G'S	77T095	1904 6410	25	44	271	595	1144

Tests = SLD/MCI FRAC

Sensors = LUR LLR

LPO3

FILTER ESTIMATION

7 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	313	784	1237	1476	1889
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	510	1020	1434	1650	2018
611. -30.4 <-----	Adjusted Asymptote (Hz) =	767	964	1303	1637	2780
	Best-Fit Filter (Hz) =	611	876	1258	1609	2771

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>					
1-2564	03.	AC LUR Y G'S	76T029	1792 6410	304	646	983	1252	1809	
1-2581	03.	AC LUR Y G'S	76T034	1522 6410	199	1158	1516	1706	2044	
1-2600	03.	AC LUR Y G'S	76T039	1760 6410	715	1160	1393	1573	1886	
1-2869	02.	AC LUR Y G'S	77T095	1904 6410	363	751	1272	1613	2080	
1-2888	02.	AC LUR Y G'S	77T098	1856 6410	136	556	1016	1255	1701	
1-2580	02.	AC LLR X G'S	76T034	1522 6410	365	698	1327	1516	1809	
1-2870	03.	AC LLR X G'S	77T095	1904 6410	377	720	1246	1477	1922	

Tests = SLD/MCI FRAC

Sensors = RUR RLR

LP04

FILTER ESTIMATION

4 Signals

SUMMARY OF SPECTRAL ANALYSIS

			Cumulative P.S.D. (%) =	50	75	90	95	99
			% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit			Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF			MEAN LOG Frequency (Hz) =	60	271	608	893	1438
<u>(Hz)</u>	<u>(dB/dec)</u>		MEAN+1SD Frequency (Hz) =	165	1048	1589	1649	1783
212.	-13.6	<-----	Adjusted Asymptote (Hz) =	353	588	1154	1920	6271
			Best-Fit Filter (Hz) =	212	476	1068	1849	6225

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2583	05.	AC RUR Y G'S	76T034	1522 6410	72	837	1271	1469	1798
1-2871	04.	AC RUR Y G'S	77T095	1904 6410	266	571	890	1105	1380
1-2890	04.	AC RUR Y G'S	77T098	1856 6410	42	416	1034	1250	1671
1-2891	05.	AC RLR X G'S	77T098	1856 6410	16	27	117	313	1031

Tests = SLD/RIG NOFX

Sensors = LLR

LP05

FILTER ESTIMATION

4 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	188	423	697	931	1578
<u>(Hz)</u> <u>(dB/dec)</u>	MEAN+1SD Frequency (Hz) =	415	1067	1745	1797	2098
510.	-23.1 <---- Adjusted Asymptote (Hz) =	689	929	1381	1864	3737
	Best-Fit Filter (Hz) =	510	820	1320	1823	3720

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2384	04.	AC LLR X G'S	76T003	1616 6410	61	86	144	299	966
1-2428	04.	AC LLR X G'S	76T009	3568 6410	131	797	1238	1330	1862
1-2449	04.	AC LLR X G'S	76T010	1496 6410	382	631	977	1268	1786
1-2470	04.	AC LLR X G'S	76T011	1542 6410	410	743	1354	1487	1931

Tests = SLD/RIG NOFX

Sensors = RUR RLR

LP06

FILTER ESTIMATION

9 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	53	176	411	606	1382
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	189	622	1141	1396	1983
257. -17.7 <----	Adjusted Asymptote (Hz) =	381	563	946	1399	3474
	Best-Fit Filter (Hz) =	257	478	891	1359	3454

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>					
1-2387	07.	AC RUR Y G'S	76T003	1616 6410	11	22	86	155	689	
1-2452	07.	AC RUR Y G'S	76T010	1496 6410	264	728	1211	1521	2080	
1-2833	04.	AC RUR Y G'S	77T089	1422 6410	22	39	103	203	1194	
1-2852	04.	AC RUR Y G'S	77T092	1872 6410	25	249	801	1081	1704	
1-2386	06.	AC RLR X G'S	76T003	1616 6410	19	58	167	271	919	
1-2451	06.	AC RLR X G'S	76T010	1496 6410	20	106	244	487	1149	
1-2472	06.	AC RLR X G'S	76T011	1542 6410	377	660	956	1218	2081	
1-2834	05.	AC RLR X G'S	77T089	1422 6410	233	664	1064	1282	1649	
1-2853	05.	AC RLR X G'S	77T092	1872 6410	64	385	945	1033	1746	

Tests = SLD/RIG FRAC

Sensors = LUR LLR

LP07

FILTER ESTIMATION

8 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+1SD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	218	550	1164	1454	1884	
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	398	919	1383	1659	2145	
496.	-25.1 <-----	Adjusted Asymptote (Hz) =	654	863	1244	1640	3118
		Best-Fit Filter (Hz) =	496	769	1193	1607	3106

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2385	05.	AC LUR Y G'S	76T003	1616	6410	296	662	975	1163	1581
1-2429	05.	AC LUR Y G'S	76T009	3568	6410	125	244	1127	1319	1484
1-2450	05.	AC LUR Y G'S	76T010	1496	6410	332	815	1233	1770	2125
1-2471	05.	AC LUR Y G'S	76T011	1542	6410	634	1136	1443	1656	2116
1-2831	02.	AC LUR Y G'S	77T089	1422	6410	91	465	861	1294	1903
1-2850	02.	AC LUR Y G'S	77T092	1872	6410	133	412	1067	1410	1839
1-2832	03.	AC LLR X G'S	77T089	1422	6410	313	944	1448	1581	2041
1-2851	03.	AC LLR X G'S	77T092	1872	6410	172	310	1293	1537	2105

Tests = SLD/RIG FRAC

Sensors = RUR RLR

LP08

FILTER ESTIMATION

3 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+LSD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	271	727	1286	1510	1886
(Hz) (dB/dec)	MEAN+LSD Frequency (Hz) =	553	1100	1552	1741	2048
658. -31.0 <-----	Adjusted Asymptote (Hz) =	823	1029	1383	1729	2905
	Best-Fit Filter (Hz) =	658	938	1336	1701	2895

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2431	07.	AC RUR Y G'S	76T009	3568 6410	146	435	986	1235	1679
1-2473	07.	AC RUR Y G'S	76T011	1542 6410	737	1196	1493	1651	1977
1-2430	06.	AC RLR X G'S	76T009	3568 6410	185	740	1444	1689	2020

Tests = PEN/L-R NOFX

Sensors = LUR LLR

LP09

FILTER ESTIMATION

6 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	97	182	405	540	1385
<u>(Hz)</u> <u>(dB/dec)</u>	MEAN+1SD Frequency (Hz) =	366	622	1142	1304	1999
422. -26.1 <----	Adjusted Asymptote (Hz) =	550	718	1019	1329	2462
	Best-Fit Filter (Hz) =	422	643	979	1303	2452

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2695	02.	AC LUR Y G'S	76T065	1376	6410	34	58	131	191	961
1-2728	02.	AC LUR Y G'S	77T071	1232	6410	23	44	135	211	961
1-2696	03.	AC LLR X G'S	76T065	1376	6410	72	110	172	297	961
1-2736	10.	AC LLR X G'S	77T071	1232	6410	41	149	961	964	2133
1-2746	03.	AC LLR X G'S	77T074	1216	6410	718	1144	1388	1567	1948
1-2763	03.	AC LLR X G'S	77T077	1232	6410	493	764	1086	1374	1915

Tests = PEN/L-R NOFX

Sensors = RUR RLR

LP10

FILTER ESTIMATION

12 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	22	102	295	664	1492
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	38	323	864	1884	1942
62.	-9.6 <---- Adjusted Asymptote (Hz) =	127	261	677	1392	7420
	Best-Fit Filter (Hz) =	62	193	606	1319	7342

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2681	04.	AC RUR Y G'S	76T062	1456	6410	17	49	125	961	1554
1-2697	04.	AC RUR Y G'S	76T065	1376	6410	16	30	58	75	962
1-2729	03.	AC RUR Y G'S	77T071	1232	6410	22	959	964	1225	2662
1-2747	04.	AC RUR Y G'S	77T074	1216	6410	25	52	454	1171	1617
1-2764	04.	AC RUR Y G'S	77T077	1232	6410	16	80	513	909	1443
1-2781	04.	AC RUR Y G'S	77T080	1232	6410	78	693	1399	1609	1939
1-2682	05.	AC RLR X G'S	76T062	1456	6410	16	72	211	842	1307
1-2698	05.	AC RLR X G'S	76T065	1376	6410	20	56	254	961	1383
1-2730	04.	AC RLR X G'S	77T071	1232	6410	14	20	38	59	962
1-2748	05.	AC RLR X G'S	77T074	1216	6410	14	92	182	958	1518
1-2765	05.	AC RLR X G'S	77T077	1232	6410	61	363	628	973	1574
1-2782	05.	AC RLR X G'S	77T080	1232	6410	17	113	814	1089	1628

Tests = SLD/MCI NOFX

Sensors = UST LST T01 T12

LP11

FILTER ESTIMATION

34 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+LSD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	47	152	431	734	1294	
(Hz) (dB/dec)	MEAN+LSD Frequency (Hz) =	139	572	1437	1991	2723	
200.	-13.6 <----	Adjusted Asymptote (Hz) =	334	557	1094	1822	5966
		Best-Fit Filter (Hz) =	200	450	1012	1754	5922

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>					
1-2575	14.	AC UST X G'S	76T029	1790 6410	72	385	961	1050	1335	
1-2592	14.	AC UST X G'S	76T034	1760 6410	174	1080	1496	1689	2413	
1-2611	14.	AC UST X G'S	76T039	1760 6410	102	557	1120	1529	1883	
1-2873	06.	AC UST X G'S	77T095	1904 6410	70	299	1031	1182	1588	
1-2892	06.	AC UST X G'S	77T098	1856 6410	92	362	875	1003	1685	
1-2576	15.	AC LST X G'S	76T029	1790 6410	31	69	793	1235	1689	
1-2593	15.	AC LST X G'S	76T034	1760 6410	33	127	767	1216	1754	
1-2612	15.	AC LST X G'S	76T039	1760 6410	5	9	14	17	27	
1-2874	07.	AC LST X G'S	77T095	1904 6410	42	1055	1397	1559	1797	
1-2893	07.	AC LST X G'S	77T098	1856 6410	41	72	516	706	1560	
1-2567	06.	AC T01 X G'S	76T029	1792 6410	44	582	1019	1200	1629	
1-2568	07.	AC T01 Z G'S	76T029	1792 6410	77	150	701	1185	1588	
1-2584	06.	AC T01 X G'S	76T034	1522 6410	593	975	1344	1444	1850	
1-2585	07.	AC T01 Z G'S	76T034	1522 6410	136	778	1027	1479	1736	
1-2603	06.	AC T01 X G'S	76T039	1760 6410	167	471	798	1208	1621	
1-2604	07.	AC T01 Z G'S	76T039	1760 6410	27	49	136	437	1013	
1-2875	08.	AC T01 X G'S	77T095	1904 6410	438	994	1452	1742	2105	
1-2876	09.	AC T01 Y G'S	77T095	1904 6410	20	149	363	833	1338	
1-2877	10.	AC T01 Z G'S	77T095	1904 6410	147	410	948	1074	1570	
1-2894	08.	AC T01 X G'S	77T098	1856 6410	83	222	653	1186	1515	
1-2895	09.	AC T01 Y G'S	77T098	1856 6410	19	56	114	269	856	
1-2896	10.	AC T01 Z G'S	77T098	1856 6410	95	177	499	983	1421	
1-2569	08.	AC T12 X G'S	76T029	1792 6410	41	78	351	808	1393	
1-2570	09.	AC T12 Y G'S	76T029	1792 6410	19	44	230	610	1282	
1-2586	08.	AC T12 X G'S	76T034	1522 6410	80	271	1131	1404	1892	
1-2587	09.	AC T12 Y G'S	76T034	1522 6410	17	44	64	136	812	
1-2605	08.	AC T12 X G'S	76T039	1760 6410	8	13	28	64	437	
1-2606	09.	AC T12 Y G'S	76T039	1760 6410	9	17	55	480	1505	
1-2879	12.	AC T12 X G'S	77T095	1902 6410	41	102	746	1156	1740	
1-2880	13.	AC T12 Y G'S	77T095	1902 6410	8	16	72	153	948	
1-2881	14.	AC T12 Z G'S	77T095	1902 6410	22	78	460	961	1567	
1-2898	12.	AC T12 X G'S	77T098	1856 6410	83	141	676	1171	1786	
1-2899	13.	AC T12 Y G'S	77T098	1856 6410	17	50	144	554	1078	
1-2900	14.	AC T12 Z G'S	77T098	1856 6410	50	559	962	1203	1740	

Tests = SLD/RIG NOFX

Sensors = UST LST T01 T12

LP12

FILTER ESTIMATION

39 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+LSD fit						
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	62	178	486	738	1355
(Hz) (dB/dec)	MEAN+LSD Frequency (Hz) =	164	399	1020	1372	1871
208.	-16.9 <---- Adjusted Asymptote (Hz) =	314	474	816	1231	3200
	Best-Fit Filter (Hz) =	208	399	767	1194	3180

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2382	02.	AC UST X G'S	76T003	1616	6410	78	678	1017	1247	1840
1-2447	02.	AC UST X G'S	76T010	1496	6410	52	257	981	1449	2027
1-2468	02.	AC UST X G'S	76T011	1542	6410	50	89	427	729	1327
1-2835	06.	AC UST X G'S	77T089	1422	6410	183	484	1063	1540	2052
1-2854	06.	AC UST X G'S	77T092	1872	6410	47	75	429	909	1613
1-2383	03.	AC LST X G'S	76T003	1616	6410	30	52	113	233	1216
1-2427	03.	AC LST X G'S	76T009	3568	6410	59	119	958	1077	1387
1-2448	03.	AC LST X G'S	76T010	1496	6410	28	81	285	825	1538
1-2469	03.	AC LST X G'S	76T011	1542	6410	41	70	103	180	1066
1-2836	07.	AC LST X G'S	77T089	1422	6410	45	103	424	931	1429
1-2855	07.	AC LST X G'S	77T092	1872	6410	45	166	507	681	1338
1-2388	08.	AC T01 X G'S	76T003	1616	6410	45	108	158	219	764
1-2389	09.	AC T01 Z G'S	76T003	1616	6410	110	156	199	255	454
1-2432	08.	AC T01 X G'S	76T009	3568	6410	183	321	911	1006	1670
1-2433	09.	AC T01 Z G'S	76T009	3568	6410	67	178	858	994	1676
1-2453	08.	AC T01 X G'S	76T010	1496	6410	45	85	213	693	1268
1-2454	09.	AC T01 Z G'S	76T010	1496	6410	74	105	266	405	961
1-2474	08.	AC T01 X G'S	76T011	1542	6410	125	236	387	933	1397
1-2475	09.	AC T01 Z G'S	76T011	1542	6410	99	368	757	950	1407
1-2837	08.	AC T01 X G'S	77T089	1422	6410	471	875	1228	1397	1756
1-2838	09.	AC T01 Y G'S	77T089	1422	6410	183	626	969	1243	1660
1-2839	10.	AC T01 Z G'S	77T089	1422	6410	352	761	1183	1347	1721
1-2856	08.	AC T01 X G'S	77T092	1872	6410	332	518	951	1216	1721
1-2857	09.	AC T01 Y G'S	77T092	1872	6410	44	239	512	629	1147
1-2858	10.	AC T01 Z G'S	77T092	1872	6410	238	321	435	692	1092
1-2390	10.	AC T12 X G'S	76T003	1616	6410	3	247	962	1031	2349
1-2391	11.	AC T12 Y G'S	76T003	1616	6410	9	219	961	1041	1737
1-2434	10.	AC T12 X G'S	76T009	3568	6410	135	379	961	1039	1454
1-2435	11.	AC T12 Y G'S	76T009	3568	6410	47	92	275	604	1225
1-2455	10.	AC T12 X G'S	76T010	1496	6410	53	91	958	1211	1634
1-2456	11.	AC T12 Y G'S	76T010	1496	6410	34	94	601	1238	1958
1-2476	10.	AC T12 X G'S	76T011	1542	6410	110	296	920	1224	1443
1-2477	11.	AC T12 Y G'S	76T011	1542	6410	64	194	476	829	1319
1-2841	12.	AC T12 X G'S	77T089	1232	6410	81	119	424	737	1254
1-2842	13.	AC T12 Y G'S	77T089	1232	6410	17	53	153	275	961
1-2843	14.	AC T12 Z G'S	77T089	1232	6410	56	405	820	1042	1487
1-2860	12.	AC T12 X G'S	77T092	1872	6410	41	88	141	228	962
1-2861	13.	AC T12 Y G'S	77T092	1872	6410	13	33	119	191	595
1-2862	14.	AC T12 Z G'S	77T092	1872	6410	45	196	654	995	1413

Tests = PEN/L-R NOFX

Sensors = UST LST T01 T12

LPL3

FILTER ESTIMATION

44 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	33	91	252	600	1219
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	76	261	720	1178	1615
106. -13.4 <----	Adjusted Asymptote (Hz) =	177	296	586	983	3259
	Best-Fit Filter (Hz) =	106	239	542	946	3234

T-File	Ch	Signal	Test ID	Sampling	Freq. (Hz) @ Cum. PSD Levels					
1-2683	06.	AC UST X G'S	76T062	1456 6410	44	74	172	455	1648	
1-2699	06.	AC UST X G'S	76T065	1376 6410	30	44	58	72	394	
1-2731	05.	AC UST X G'S	77T071	1232 6410	16	44	203	961	1449	
1-2749	06.	AC UST X G'S	77T074	1216 6410	42	59	88	465	1207	
1-2766	06.	AC UST X G'S	77T077	1232 6410	45	167	369	959	1505	
1-2783	06.	AC UST X G'S	77T080	1232 6410	106	125	199	319	964	
1-2684	07.	AC LST X G'S	76T062	1456 6410	42	67	225	599	1269	
1-2732	06.	AC LST X G'S	77T071	1232 6410	30	49	75	91	961	
1-2767	07.	AC LST X G'S	77T077	1232 6410	64	224	499	854	1336	
1-2784	07.	AC LST X G'S	77T080	1232 6410	99	174	299	618	1022	
1-2685	08.	AC T01 X G'S	76T062	1456 6410	2	36	274	834	1468	
1-2701	08.	AC T01 X G'S	76T065	1376 6410	14	31	117	950	1346	
1-2702	09.	AC T01 Z G'S	76T065	1376 6410	25	202	956	980	1603	
1-2703	10.	AC T01 Y G'S	76T065	1376 6410	13	20	38	218	1013	
1-2733	07.	AC T01 X G'S	77T071	1232 6410	34	63	562	867	1268	
1-2734	08.	AC T01 Y G'S	77T071	1232 6410	23	116	959	962	1779	
1-2735	09.	AC T01 Z G'S	77T071	1232 6410	9	17	39	383	1141	
1-2751	08.	AC T01 X G'S	77T074	1216 6410	89	186	576	964	1692	
1-2752	09.	AC T01 Y G'S	77T074	1216 6410	13	20	53	175	1028	
1-2753	10.	AC T01 Z G'S	77T074	1216 6410	38	216	297	369	1221	
1-2768	08.	AC T01 X G'S	77T077	1232 6410	131	186	390	959	1383	
1-2769	09.	AC T01 Y G'S	77T077	1232 6410	13	34	147	216	962	
1-2770	10.	AC T01 Z G'S	77T077	1232 6410	42	249	753	1036	1505	
1-2785	08.	AC T01 X G'S	77T080	1232 6410	102	293	512	959	1496	
1-2786	09.	AC T01 Y G'S	77T080	1232 6410	11	17	111	210	961	
1-2787	10.	AC T01 Z G'S	77T080	1232 6410	110	221	319	393	962	
1-2689	12.	AC T12 X G'S	76T062	1456 6410	28	39	260	931	1191	
1-2690	13.	AC T12 Z G'S	76T062	1456 6410	63	178	505	851	983	
1-2691	14.	AC T12 Y G'S	76T062	1456 6410	25	63	116	315	964	
1-2705	12.	AC T12 X G'S	76T065	1374 6410	25	38	144	961	1448	
1-2706	13.	AC T12 Z G'S	76T065	1374 6410	22	91	961	964	1618	
1-2707	14.	AC T12 Y G'S	76T065	1374 6410	19	33	56	959	1025	
1-2738	12.	AC T12 X G'S	77T071	1232 6410	23	31	44	490	966	
1-2739	13.	AC T12 Y G'S	77T071	1232 6410	16	23	36	790	966	
1-2740	14.	AC T12 Z G'S	77T071	1232 6410	28	66	823	962	1599	
1-2755	12.	AC T12 X G'S	77T074	1214 6410	14	23	63	293	961	
1-2756	13.	AC T12 Y G'S	77T074	1214 6410	45	808	962	966	2111	
1-2757	14.	AC T12 Z G'S	77T074	1214 6410	45	80	441	815	1122	
1-2772	12.	AC T12 X G'S	77T077	1232 6410	222	405	648	761	983	
1-2773	13.	AC T12 Y G'S	77T077	1232 6410	56	950	964	1064	2108	
1-2774	14.	AC T12 Z G'S	77T077	1232 6410	49	213	808	962	1302	
1-2789	12.	AC T12 X G'S	77T080	1232 6410	55	202	782	966	1369	
1-2790	13.	AC T12 Y G'S	77T080	1232 6410	27	407	568	762	1023	
1-2791	14.	AC T12 Z G'S	77T080	1232 6410	47	396	814	962	1297	

Tests = SLD/ABG NOFX

Sensors = LUR LLR RUR RLR

LP14

FILTER ESTIMATION

18 Signals

SUMMARY OF SPECTRAL ANALYSIS

Cumulative P.S.D. (%) =	50	75	90	95	99
% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit					
Equivalent Filter (dB) =	-3	-6	-10	-13	-20
MEAN LOG Frequency (Hz) =	23	82	222	441	1183
MEAN+1SD Frequency (Hz) =	102	408	939	1633	1741
CORNER @ ROLL-OFF					
(Hz) (dB/dec)	143.	-13.6	<----	Adjusted Asymptote (Hz) =	237 395 775 1291 4215
				Best-Fit Filter (Hz) =	143 320 717 1243 4184

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>					
1-2258	05.	AC LUR Y G'S	A-887	1958 6410	6	9	59	826	1110	
1-2277	05.	AC LUR Y G'S	A-923	1796 6410	34	78	208	421	970	
1-2300	05.	AC LUR Y G'S	A-924	1648 6410	188	900	1102	1277	1717	
1-2322	05.	AC LUR Y G'S	A-927	1648 6410	662	1047	1372	1545	1837	
1-2257	04.	AC LLR X G'S	A-887	1958 6410	6	13	19	27	961	
1-2276	04.	AC LLR X G'S	A-923	1796 6410	20	33	58	116	513	
1-2299	04.	AC LLR X G'S	A-924	1648 6410	13	164	551	1318	1715	
1-2321	04.	AC LLR X G'S	A-927	1648 6410	31	189	884	1128	1471	
1-2495	08.	AC LLR X G'S	76T020	1600 6410	8	34	725	1156	1679	
1-2260	07.	AC RUR Y G'S	A-887	1958 6410	6	11	59	826	1277	
1-2279	07.	AC RUR Y G'S	A-923	1796 6410	33	75	110	182	822	
1-2302	07.	AC RUR Y G'S	A-924	1648 6410	11	609	1124	1282	1653	
1-2498	11.	AC RUR Y G'S	76T020	1600 6410	712	1080	1372	1543	1864	
1-2259	06.	AC RLR X G'S	A-887	1958 6410	6	13	19	23	961	
1-2278	06.	AC RLR X G'S	A-923	1796 6410	19	45	75	114	521	
1-2301	06.	AC RLR X G'S	A-924	1648 6410	6	41	371	621	1366	
1-2323	06.	AC RLR X G'S	A-927	1648 6410	36	352	593	823	1369	
1-2497	10.	AC RLR X G'S	76T020	1600 6410	6	22	77	268	964	

Tests = SLD/ABG FRAC

Sensors = RUR LUR

LP15

FILTER ESTIMATION

2 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	896	1325	1683	1880	2326
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	917	1326	1687	1903	2452
1012. -46.6 <----	Adjusted Asymptote (Hz) =	1174	1362	1658	1924	2717
	Best-Fit Filter (Hz) =	1012	1280	1621	1903	2711

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2324	07.	AC RUR Y G'S	A-927	1648 6410	876	1324	1679	1858	2207
1-2496	09.	AC LUR Y G'S	76T020	1600 6410	917	1326	1687	1903	2452

Tests = SLD/ABG NOFX

Sensors = UST LST

LP16

FILTER ESTIMATION

9 Signals

SUMMARY OF SPECTRAL ANALYSIS

		Cumulative P.S.D. (%) =	50	75	90	95	99
		% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit		Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF		MEAN LOG Frequency (Hz) =	9	21	75	136	737
(Hz)	(dB/dec)	MEAN+1SD Frequency (Hz) =	12	35	274	510	1901
15.	-8.6 <----	Adjusted Asymptote (Hz) =	33	75	217	486	3168
		Best-Fit Filter (Hz) =	15	53	191	458	3131

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>					
1-2255	02.	AC UST X G'S	A-887	1958	6410	6	9	16	22	961	
1-2274	02.	AC UST X G'S	A-923	1796	6410	6	17	44	55	153	
1-2319	02.	AC UST X G'S	A-927	1648	6410	9	22	67	266	1311	
1-2493	06.	AC UST X G'S	76T020	1600	6410	11	36	953	1352	1958	
1-2256	03.	AC LST X G'S	A-887	1958	6410	9	17	38	56	961	
1-2275	03.	AC LST X G'S	A-923	1796	6410	6	20	33	38	114	
1-2298	03.	AC LST X G'S	A-924	1648	6410	13	53	598	786	1416	
1-2320	03.	AC LST X G'S	A-927	1648	6410	14	30	59	106	959	
1-2494	07.	AC LST X G'S	76T020	1600	6410	8	14	38	213	1147	

Tests = SLD/ABG NOFX

Sensors = T01 T12

LP17

FILTER ESTIMATION

20 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	25	75	238	403	1029
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	127	298	770	1125	1759
159. -16.2 <----	Adjusted Asymptote (Hz) =	244	375	660	1012	2731
	Best-Fit Filter (Hz) =	159	314	618	980	2714

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2265	12.	AC T01 X G'S	A-887	1536	6410	959	962	1509	1912	2886
1-2266	13.	AC T01 Z G'S	A-887	1536	6410	8	25	63	235	1117
1-2285	13.	AC T01 X G'S	A-923	1648	6410	8	22	58	89	419
1-2286	14.	AC T01 Z G'S	A-923	1648	6410	19	50	205	230	419
1-2308	13.	AC T01 X G'S	A-924	1648	6410	169	279	463	823	1509
1-2309	14.	AC T01 Z G'S	A-924	1648	6410	17	200	283	377	898
1-2330	13.	AC T01 X G'S	A-927	1648	6410	25	122	222	376	1019
1-2331	14.	AC T01 Z G'S	A-927	1648	6410	6	22	102	260	682
1-2489	02.	AC T01 X G'S	76T020	1600	6410	5	17	160	493	1019
1-2490	03.	AC T01 Z G'S	76T020	1600	6410	50	221	343	668	1164
1-2267	14.	AC T12 X G'S	A-887	1536	6410	5	11	22	52	967
1-2268	15.	AC T12 Y G'S	A-887	1536	6410	58	88	718	962	1659
1-2287	15.	AC T12 X G'S	A-923	1648	6410	5	13	30	42	341
1-2288	16.	AC T12 Y G'S	A-923	1648	6410	31	39	106	177	584
1-2310	15.	AC T12 X G'S	A-924	1648	6410	3	23	147	408	962
1-2311	16.	AC T12 Y G'S	A-924	1648	6410	58	257	670	967	1981
1-2332	15.	AC T12 X G'S	A-927	1648	6410	294	626	1019	1183	1466
1-2333	16.	AC T12 Y G'S	A-927	1648	6410	172	219	556	862	1527
1-2491	04.	AC T12 X G'S	76T020	1600	6410	3	14	732	959	1374
1-2492	05.	AC T12 Y G'S	76T020	1600	6410	81	365	875	967	1504

Tests = SLD/3PT NOFX

Sensors = LUR LLR

LP18

FILTER ESTIMATION

2 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	6	67	135	178	1296
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	13	746	1077	1271	1745
21. -6.6 <-----	Adjusted Asymptote (Hz) =	60	172	690	1970	22550
	Best-Fit Filter (Hz) =	21	111	588	1823	22210

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2407	09.	AC LUR Y G'S	76T008	1488	6410	13	746	1077	1271	1745
1-2406	08.	AC LLR X G'S	76T008	1488	6410	3	6	17	25	962

Tests = SLD/3PT FRAC

Sensors = RUR RLR

LP19

FILTER ESTIMATION

2 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	28	64	863	1107	1618
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	263	518	897	1189	1831
316. -23.1 <-----	Adjusted Asymptote (Hz) =	426	576	856	1155	2318
	Best-Fit Filter (Hz) =	316	508	817	1130	2307

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>						
1-2409	11.	AC RUR Y G'S	76T008	1488 6410	263	518	897	1031	1430		
1-2408	10.	AC RLR X G'S	76T008	1488 6410	3	8	831	1189	1831		

Tests = SLD/3PT NOFX

Sensors = T01 T12

LP20

FILTER ESTIMATION

4 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	6	19	164	307	1255
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	18	84	981	2107	1599
23.	-7.5 <-----	Adjusted Asymptote (Hz) =	57	143	484	1216 10340
		Best-Fit Filter (Hz) =	23	98	420	1136 10202

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2400	02.	AC T01 X G'S	76T008	1488	6410	2	9	285	803	1421
1-2401	03.	AC T01 Z G'S	76T008	1488	6410	9	34	385	1025	1429
1-2402	04.	AC T12 X G'S	76T008	1488	6410	2	3	8	11	825
1-2403	05.	AC T12 Y G'S	76T008	1488	6410	30	153	829	986	1479

Tests = SLD/LAP NOFX

Sensors = LUR LLR RUR RLR

LP21

FILTER ESTIMATION

23 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	47	176	468	798	1541
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	201	765	1376	1904	1995
271. -16.2 <-----	Adjusted Asymptote (Hz) =	415	636	1118	1713	4614
	Best-Fit Filter (Hz) =	271	533	1048	1660	4586

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>					
1-2159	05.	AC LUR Y G'S	A-877	2462 6410	50	186	490	923	1679	
1-2180	05.	AC LUR Y G'S	A-880	1588 6410	86	462	890	1150	1598	
1-2237	04.	AC LUR Y G'S	A-884	1760 6410	454	951	1335	1567	1961	
1-2343	05.	AC LUR Y G'S	A-928	1648 6410	50	288	962	1161	1998	
1-2364	05.	AC LUR Y G'S	A-937	1616 6410	94	473	1038	1474	1905	
1-2158	04.	AC LLR X G'S	A-877	2462 6410	11	22	97	388	1072	
1-2179	04.	AC LLR X G'S	A-880	1588 6410	94	562	1222	1379	1715	
1-2218	04.	AC LLR X G'S	A-883	2016 6410	16	236	706	1023	1582	
1-2236	03.	AC LLR X G'S	A-884	1760 6410	3	14	338	900	1404	
1-2342	04.	AC LLR X G'S	A-928	1648 6410	27	41	50	67	962	
1-2363	04.	AC LLR X G'S	A-937	1616 6410	36	55	169	565	1308	
1-2161	07.	AC RUR Y G'S	A-877	2462 6410	424	1016	1404	1637	2230	
1-2182	07.	AC RUR Y G'S	A-880	1588 6410	139	207	588	809	1247	
1-2221	07.	AC RUR Y G'S	A-883	2016 6410	1002	1341	1646	1828	2258	
1-2239	06.	AC RUR Y G'S	A-884	1760 6410	352	808	1158	1521	2089	
1-2345	07.	AC RUR Y G'S	A-928	1648 6410	20	34	175	961	1354	
1-2366	07.	AC RUR Y G'S	A-937	1616 6410	16	883	1358	1538	1887	
1-2160	06.	AC RLR X G'S	A-877	2462 6410	8	16	88	166	962	
1-2181	06.	AC RLR X G'S	A-880	1588 6410	169	1086	1368	1504	1717	
1-2220	06.	AC RLR X G'S	A-883	2016 6410	17	66	324	621	1404	
1-2238	05.	AC RLR X G'S	A-884	1760 6410	11	290	937	1172	1681	
1-2344	06.	AC RLR X G'S	A-928	1648 6410	28	42	85	111	961	
1-2365	06.	AC RLR X G'S	A-937	1616 6410	13	44	158	970	1621	

Tests = SLD/LAP NOFX

Sensors = UST LST

LP22

FILTER ESTIMATION

8 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+1SD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	28	92	223	408	1103	
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	121	316	766	1418	1870	
155.	-15.1 <-----	Adjusted Asymptote (Hz) =	245	387	709	1120	3241
		Best-Fit Filter (Hz) =	155	320	661	1082	3219

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2156	02.	AC UST X G'S	A-877	2462	6410	19	182	613	945	1432
1-2361	02.	AC UST X G'S	A-937	1616	6410	19	41	50	69	341
1-2157	03.	AC LST X G'S	A-877	2462	6410	41	189	573	961	1573
1-2178	03.	AC LST X G'S	A-880	1588	6410	27	56	271	815	1437
1-2217	03.	AC LST X G'S	A-883	2016	6410	9	25	39	66	804
1-2235	02.	AC LST X G'S	A-884	1760	6410	1020	1341	1621	1853	2147
1-2341	03.	AC LST X G'S	A-928	1648	6410	16	67	249	879	1243
1-2362	03.	AC LST X G'S	A-937	1616	6410	6	30	83	139	925

Tests = SLD/LAP FRAC

Sensors = UST

LP23

FILTER ESTIMATION

3 Signals

SUMMARY OF SPECTRAL ANALYSIS

Cumulative P.S.D. (%) =	50	75	90	95	99		
% of Signal Passed (%) =	71	50	32	22	10		
Best MEAN+1SD fit							
EQUIVALENT FILTER (dB) =	-3	-6	-10	-13	-20		
CORNER @ ROLL-OFF (Hz) (dB/dec)	MEAN LOG Frequency (Hz) =	23	185	407	598	1511	
	MEAN+1SD Frequency (Hz) =	48	732	1802	2091	2134	
74.	-8.7 <-----	Adjusted Asymptote (Hz) =	164	363	1038	2298	14535
		Best-Fit Filter (Hz) =	74	261	920	2166	14369

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2177	02.	AC UST X G'S	A-880	1588 6410	64	371	1000	1351	1615
1-2216	02.	AC UST X G'S	A-883	2016 6410	17	629	1349	1552	2222
1-2340	02.	AC UST X G'S	A-928	1648 6410	11	27	50	102	962

Tests = SLD/LAP NOFX

Sensors = T01 T12

LP24

FILTER ESTIMATION

20 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+1SD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	32	134	371	559	1287	
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	125	454	1092	1496	1757	
172.	-14.7 <-----	Adjusted Asymptote (Hz) =	275	442	826	1325	3972
		Best-Fit Filter (Hz) =	172	363	768	1279	3944

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>					
1-2167	13.	AC T01 X G'S	A-877	2064 6410	16	25	246	427	854	
1-2168	14.	AC T01 Z G'S	A-877	2064 6410	69	239	426	668	1038	
1-2245	12.	AC T01 X G'S	A-884	1472 6410	13	269	905	1191	1631	
1-2246	13.	AC T01 Z G'S	A-884	1472 6410	8	254	941	1211	1678	
1-2351	13.	AC T01 X G'S	A-928	1630 6410	30	49	59	174	964	
1-2352	14.	AC T01 Z G'S	A-928	1630 6410	17	27	44	56	959	
1-2372	13.	AC T01 X G'S	A-937	1616 6410	38	64	357	435	1042	
1-2373	14.	AC T01 Z G'S	A-937	1616 6410	17	41	311	421	948	
1-2169	15.	AC T12 X G'S	A-877	2064 6410	33	105	214	344	964	
1-2170	16.	AC T12 Y G'S	A-877	2064 6410	50	318	480	919	1352	
1-2190	15.	AC T12 X G'S	A-880	1664 6410	16	52	397	488	950	
1-2191	16.	AC T12 Y G'S	A-880	1664 6410	124	402	596	809	1233	
1-2227	13.	AC T12 X G'S	A-883	1660 6410	9	205	326	565	1341	
1-2228	14.	AC T12 Y G'S	A-883	1660 6410	36	316	895	1125	1718	
1-2247	14.	AC T12 X G'S	A-884	1472 6410	5	286	939	1208	1648	
1-2248	15.	AC T12 Y G'S	A-884	1472 6410	277	779	1213	1443	1894	
1-2353	15.	AC T12 X G'S	A-928	1630 6410	11	19	25	44	962	
1-2354	16.	AC T12 Y G'S	A-928	1630 6410	959	962	1462	1989	2887	
1-2374	15.	AC T12 X G'S	A-937	1616 6410	9	23	394	967	1399	
1-2375	16.	AC T12 Y G'S	A-937	1616 6410	308	552	829	1016	1654	

Tests = SLD/LAP FRAC

Sensors = T01

LP25

FILTER ESTIMATION

2 Signals

SUMMARY OF SPECTRAL ANALYSIS

			Cumulative P.S.D. (%) =	50	75	90	95	99
			% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit			Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF			MEAN LOG Frequency (Hz) =	27	137	461	780	1362
<u>(Hz)</u>	<u>(dB/dec)</u>		MEAN+1SD Frequency (Hz) =	39	200	601	831	1410
60.	-11.6	<-----	Adjusted Asymptote (Hz) =	110	199	439	797	3184
			Best-Fit Filter (Hz) =	60	155	400	762	3156

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2188	13.	AC T01 X G'S	A-880	1664 6410	39	94	354	732	1410
1-2189	14.	AC T01 Z G'S	A-880	1664 6410	19	200	601	831	1316

Tests = PEN/A-P NOFX

Sensors = LUR LLR RUR RLR

LP26

FILTER ESTIMATION

6 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit						
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	124	290	637	972	1484
<u>(Hz)</u> <u>(dB/dec)</u>	MEAN+1SD Frequency (Hz) =	400	886	1259	1511	1924
492.	-26.9 <----	Adjusted Asymptote (Hz) =	636	823	1157	1496
		Best-Fit Filter (Hz) =	492	740	1112	1467

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2520	07.	AC LUR Y G'S	76T021	1440	6410	449	1144	1545	1767	2167
1-2532	07.	AC LUR Y G'S	76T022	1824	6410	401	748	1106	1277	1560
1-2544	07.	AC LUR Y G'S	76T024	1952	6410	42	99	246	455	898
1-2556	07.	AC LUR Y G'S	76T025	1568	6410	347	687	1041	1221	1480
1-2617	02.	AC LUR Y G'S	76T050	2144	6410	44	59	322	961	1606
1-2630	02.	AC LUR Y G'S	76T053	1402	6410	31	174	473	700	1480

Tests = PEN/A-P FRAC

Sensors = RUR

LP27

FILTER ESTIMATION

2 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	172	308	831	1280	1679
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	556	1041	1531	1706	2146
658. -31.4 <-----	Adjusted Asymptote (Hz) =	821	1024	1371	1711	2858
	Best-Fit Filter (Hz) =	658	934	1326	1683	2849

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>						
1-2534	09.	AC RUR Y G'S	76T022	1824 6410	53	91	451	961	1313		
1-2816	04.	AC RUR Y G'S	77T086	1246 6410	556	1041	1531	1706	2146		

Tests = PEN/A-P NOFX

Sensors = UST LST

LP28

FILTER ESTIMATION

11 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+1SD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	59	132	314	464	1248	
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	115	363	846	1090	1755	
158.	-15.7 <-----	Adjusted Asymptote (Hz) =	246	382	685	1066	2973
		Best-Fit Filter (Hz) =	158	318	640	1032	2954

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2621	06.	AC UST X G'S	76T050	2144	6410	22	42	961	962	1920
1-2634	06.	AC UST X G'S	76T053	1402	6410	307	1690	1923	1925	1934
1-2650	06.	AC UST X G'S	76T056	1246	6410	53	97	186	426	970
1-2667	06.	AC UST X G'S	76T059	1312	6410	36	64	158	290	961
1-2800	06.	AC UST X G'S	77T083	1232	6410	41	80	131	418	1078
1-2818	06.	AC UST X G'S	77T086	1246	6410	45	80	122	150	800
1-2635	07.	AC LST X G'S	76T053	1402	6410	50	91	128	161	962
1-2651	07.	AC LST X G'S	76T056	1246	6410	49	97	185	272	881
1-2668	07.	AC LST X G'S	76T059	1312	6410	66	130	1014	1488	2130
1-2715	06.	AC LST X G'S	77T068	1232	6410	128	573	853	1034	1626
1-2819	07.	AC LST X G'S	77T086	1246	6410	66	110	164	221	1310

Tests = PEN/A-P FRAC

Sensors = LST UST

LP29

FILTER ESTIMATION

3 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	52	102	239	460	1181
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	58	107	337	611	1237
65. -14.2 <----	Adjusted Asymptote (Hz) =	106	173	329	537	1670
	Best-Fit Filter (Hz) =	65	141	305	518	1658

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-2622	07.	AC LST X G'S	76T050	2144	6410	55	108	205	338	1160
1-2801	07.	AC LST X G'S	77T083	1232	6410	58	103	172	430	1258
1-2714	05.	AC UST X G'S	77T068	1232	6410	45	95	365	670	1128

Tests = PEN/A-P NOFX

Sensors = T01 T12

LP30

FILTER ESTIMATION

13 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+1SD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	46	235	479	742	1541	
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	167	975	1509	1703	2169	
234.	-14.3 <-----	Adjusted Asymptote (Hz) =	379	616	1170	1899	5855
		Best-Fit Filter (Hz) =	234	504	1086	1832	5814

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>								
1-2515	02.	AC T01 X G'S	76T021	1440	6410	105	598	962	1105	1762				
1-2516	03.	AC T01 Z G'S	76T021	1440	6410	196	582	962	1033	1444				
1-2527	02.	AC T01 X G'S	76T022	1824	6410	17	961	962	1028	2421				
1-2528	03.	AC T01 Z G'S	76T022	1824	6410	17	825	962	967	2297				
1-2539	02.	AC T01 X G'S	76T024	1952	6410	2	6	16	58	776				
1-2540	03.	AC T01 Z G'S	76T024	1952	6410	45	236	601	787	1149				
1-2551	02.	AC T01 X G'S	76T025	1568	6410	41	64	279	962	1601				
1-2552	03.	AC T01 Z G'S	76T025	1568	6410	280	623	1305	1407	1662				
1-2623	08.	AC T01 X G'S	76T050	2144	6410	117	961	962	1316	2565				
1-2624	09.	AC T01 Z G'S	76T050	2144	6410	185	330	534	961	1352				
1-2636	08.	AC T01 X G'S	76T053	1402	6410	19	88	189	271	964				
1-2637	09.	AC T01 Z G'S	76T053	1402	6410	30	61	249	797	1288				
1-2638	10.	AC T01 Y G'S	76T053	1402	6410	53	258	962	1075	1905				

Tests = DIR NOPAD FRAC

Sensors = HED HD1 HD2 HD3

LP31

FILTER ESTIMATION

28 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit						
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	199	595	1110	1569	3053
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	985	3043	4645	6072	7690
1303.	-19.9 <----	Adjusted Asymptote (Hz) =	1846	2615	4145	5874 13191
		Best-Fit Filter (Hz) =	1303	2263	3931	5724 13124

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>					
2-1068	18.	AC HED Y G'S	82-05	2500 10000	5	12	32	76	728	
2-1069	19.	AC HED Z G'S	82-05	2500 10000	17	24	49	66	288	
2-1068	18.	AC HED Y G'S	82-05	2500 10000	5	12	32	76	728	
2-1069	19.	AC HED Z G'S	82-05	2500 10000	17	24	49	66	288	
1-2438	14.	AC HED X G'S	76T009	1376 6410	537	844	1139	1305	1609	
1-2439	15.	AC HED Z G'S	76T009	1376 6410	210	834	1164	1545	1930	
1-2440	16.	AC HED Y G'S	76T009	1376 6410	111	466	942	1164	1626	
1-2479	13.	AC HED X G'S	76T011	1520 6410	504	1607	1934	1995	2086	
1-2480	14.	AC HED Z G'S	76T011	1520 6410	243	393	1199	1715	1994	
1-2481	15.	AC HED Y G'S	76T011	1520 6410	58	136	861	1310	2002	
1-3525	02.	AC HD1 X G'S	76A145	2560 25000	488	729	1993	2478	5276	
1-3526	03.	AC HD1 Y G'S	76A145	2560 25000	391	684	1355	1642	4642	
1-3527	04.	AC HD1 Z G'S	76A145	2560 25000	739	1364	2170	3809	5060	
1-3538	02.	AC HD1 X G'S	76A152	2560 25000	165	1266	2255	2509	4257	
1-3539	03.	AC HD1 Y G'S	76A152	2560 25000	259	2194	2707	4004	6375	
1-3540	04.	AC HD1 Z G'S	76A152	2560 25000	134	1395	2142	3299	5927	
1-3528	05.	AC HD2 Z G'S	76A145	2560 25000	55	1593	2676	4263	5795	
1-3529	06.	AC HD2 X G'S	76A145	2560 25000	76	183	1138	1306	3467	
1-3530	07.	AC HD2 Y G'S	76A145	2560 25000	1898	2521	4062	4807	6290	
1-3541	05.	AC HD2 Z G'S	76A152	2560 25000	253	2441	3430	4843	7999	
1-3542	06.	AC HD2 X G'S	76A152	2560 25000	1501	2136	2505	3409	4846	
1-3543	07.	AC HD2 Y G'S	76A152	2560 25000	638	2945	3644	5484	7425	
1-3531	08.	AC HD3 Y G'S	76A145	2560 25000	833	1074	1334	1965	4593	
1-3532	09.	AC HD3 Z G'S	76A145	2560 25000	958	1212	1379	1501	4041	
1-3533	10.	AC HD3 X G'S	76A145	2560 25000	1108	1273	1529	2463	4703	
1-3544	08.	AC HD3 Y G'S	76A152	2560 25000	131	2371	4749	5164	6863	
1-3545	09.	AC HD3 Z G'S	76A152	2560 25000	1633	2557	3241	5042	6146	
1-3546	10.	AC HD3 X G'S	76A152	2560 25000	119	693	2338	4794	7587	

Tests = DIR W/PAD FRAC

Sensors = HD1 HD2 HD3 HED

LP32

FILTER ESTIMATION

10 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+1SD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	29	92	294	673	1562	
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	64	201	813	1445	1878	
85.	-11.7 <----	Adjusted Asymptote (Hz) =	154	278	609	1099	4339
		Best-Fit Filter (Hz) =	85	217	556	1052	4301

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-3438	02.	AC HD1 X G'S	76A126	1024 10000	29	66	103	144	950
1-3439	03.	AC HD1 Y G'S	76A126	1024 10000	12	24	117	732	1677
1-3440	04.	AC HD1 Z G'S	76A126	1024 10000	12	98	818	1145	1799
1-3441	05.	AC HD2 Z G'S	76A126	1024 10000	42	76	132	217	1523
1-3442	06.	AC HD2 X G'S	76A126	1024 10000	17	59	120	425	1533
1-3443	07.	AC HD2 Y G'S	76A126	1024 10000	54	139	1060	1436	1885
1-3445	09.	AC HD3 Z G'S	76A126	1024 10000	15	49	122	796	1477
1-3446	10.	AC HD3 X G'S	76A126	1024 10000	17	81	215	820	1538
1-2212	16.	AC HED X G'S	76T042	1744 6410	69	315	1351	1579	1828
1-2213	17.	AC HED Z G'S	76T042	1744 6410	144	357	826	1164	1648

Tests = DIR NOPAD NOFX

Sensors = HD1 HD2 HD3 HED

LP33

FILTER ESTIMATION

33 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+1SD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	137	349	723	986	1649	
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	463	847	1475	1814	2508	
547.	-25.7 <-----	Adjusted Asymptote (Hz) =	716	937	1338	1752	3275
		Best-Fit Filter (Hz) =	547	838	1284	1717	3262

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>					
1-3512	02.	AC HD1 X G'S	76A144	1024 10000	156	408	828	1340	2178	
1-3513	03.	AC HD1 Y G'S	76A144	1024 10000	227	491	2043	2383	2754	
1-3514	04.	AC HD1 Z G'S	76A144	1024 10000	269	518	1858	2212	2581	
2-0002	01.	AC HD1 X G'S	MS 91	640 10000	66	239	432	652	1182	
2-0003	02.	AC HD1 Y G'S	MS 91	640 10000	49	93	183	266	974	
2-0004	03.	AC HD1 Z G'S	MS 91	640 10000	745	1006	1250	1487	1980	
2-0013	01.	AC HD1 X G'S	MS 92	640 10000	117	171	249	383	835	
2-0014	02.	AC HD1 Y G'S	MS 92	640 10000	98	164	232	493	1917	
2-0015	03.	AC HD1 Z G'S	MS 92	640 10000	669	1008	1179	1509	2715	
1-3515	05.	AC HD2 Z G'S	76A144	1024 10000	212	410	784	1096	2212	
1-3516	06.	AC HD2 X G'S	76A144	1024 10000	105	552	1321	1902	2095	
1-3517	07.	AC HD2 Y G'S	76A144	1024 10000	596	2039	2268	2432	3245	
2-0005	04.	AC HD2 X G'S	MS 91	640 10000	44	73	159	242	503	
2-0006	05.	AC HD2 Y G'S	MS 91	640 10000	63	266	425	576	1472	
2-0007	06.	AC HD2 Z G'S	MS 91	640 10000	730	933	1106	1292	2173	
2-0016	04.	AC HD2 X G'S	MS 92	640 10000	105	173	339	444	820	
2-0017	05.	AC HD2 Y G'S	MS 92	640 10000	120	164	549	725	1377	
2-0018	06.	AC HD2 Z G'S	MS 92	640 10000	178	818	1003	1216	1687	
1-3519	09.	AC HD3 Z G'S	76A144	1024 10000	686	874	1099	1719	2051	
1-3520	10.	AC HD3 X G'S	76A144	1024 10000	798	991	1467	1565	1826	
2-0008	07.	AC HD3 X G'S	MS 91	640 10000	49	100	369	745	1265	
2-0009	08.	AC HD3 Y G'S	MS 91	640 10000	315	586	1138	1497	1873	
2-0010	09.	AC HD3 Z G'S	MS 91	640 10000	66	352	474	579	713	
2-0019	07.	AC HD3 X G'S	MS 92	640 10000	85	244	933	1211	2527	
2-0020	08.	AC HD3 Y G'S	MS 92	640 10000	391	693	1174	1411	2239	
2-0021	09.	AC HD3 Z G'S	MS 92	640 10000	39	139	398	581	2024	
1-2458	13.	AC HED X G'S	76T010	1536 6410	1590	1673	1811	1847	2080	
1-2459	14.	AC HED Z G'S	76T010	1536 6410	228	659	1435	1840	2127	
1-2460	15.	AC HED Y G'S	76T010	1536 6410	89	332	695	992	1854	
2-1039	18.	AC HED Y G'S	82-04	2500 10000	12	208	952	1206	1528	
2-1040	19.	AC HED Z G'S	82-04	2500 10000	29	100	374	632	1226	
2-1039	18.	AC HED Y G'S	82-04	2500 10000	12	208	952	1206	1528	
2-1040	19.	AC HED Z G'S	82-04	2500 10000	29	100	374	632	1226	

Tests = DIR W/PAD NOFX

Sensors = HD1 HD2 HD3 HED

LP34

FILTER ESTIMATION

18 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99
	% of Signal Passed (%) =	71	50	32	22	10
Best MEAN+1SD fit	Equivalent Filter (dB) =	-3	-6	-10	-13	-20
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	26	64	145	222	942
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	42	99	345	598	2017
49. -11.8 <----	Adjusted Asymptote (Hz) =	88	159	347	625	2459
	Best-Fit Filter (Hz) =	49	124	317	598	2438

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>	<u>Freq. (Hz) @ Cum. PSD Levels</u>				
1-3425	02.	AC HD1 X G'S	75A116	2560 25000	31	64	110	146	2972
1-3426	03.	AC HD1 Y G'S	75A116	2560 25000	40	73	113	156	3287
1-3427	04.	AC HD1 Z G'S	75A116	2560 25000	18	58	1382	3751	5185
1-3412	02.	AC HD1 X G'S	75A113	1024 10000	34	61	90	112	801
1-3413	03.	AC HD1 Y G'S	75A113	1024 10000	34	63	90	115	715
1-3414	04.	AC HD1 Z G'S	75A113	1024 10000	7	27	83	186	957
1-3451	02.	AC HD1 X G'S	76A133	1024 10000	44	93	273	378	491
1-3452	03.	AC HD1 Y G'S	76A133	1024 10000	12	212	1033	1189	1326
1-3453	04.	AC HD1 Z G'S	76A133	1024 10000	22	115	447	928	1274
1-3463	02.	AC HD1 X G'S	76A134	1024 10000	22	63	103	127	740
1-3464	03.	AC HD1 Y G'S	76A134	1024 10000	39	68	100	125	654
1-3465	04.	AC HD1 Z G'S	76A134	1024 10000	22	42	81	122	1160
1-3475	02.	AC HD1 X G'S	76A135	1024 10000	34	54	73	95	759
1-3476	03.	AC HD1 Y G'S	76A135	1024 10000	34	54	81	100	347
1-3477	04.	AC HD1 Z G'S	76A135	1024 10000	15	37	76	90	232
1-3487	02.	AC HD1 X G'S	76A136	1024 10000	46	83	127	217	718
1-3488	03.	AC HD1 Y G'S	76A136	1024 10000	32	66	117	305	1289
1-3489	04.	AC HD1 Z G'S	76A136	1024 10000	24	51	98	181	466

Tests = NO DIRECT IMPACT

Sensors = HD1 HD2 HD3 HED

LP35

FILTER ESTIMATION

15 Signals

SUMMARY OF SPECTRAL ANALYSIS

	Cumulative P.S.D. (%) =	50	75	90	95	99	
	% of Signal Passed (%) =	71	50	32	22	10	
Best MEAN+1SD fit							
	Equivalent Filter (dB) =	-3	-6	-10	-13	-20	
CORNER @ ROLL-OFF	MEAN LOG Frequency (Hz) =	12	20	35	47	175	
(Hz) (dB/dec)	MEAN+1SD Frequency (Hz) =	20	35	59	88	537	
17.	-14.1 <----	Adjusted Asymptote (Hz) =	28	45	86	141	441
		Best-Fit Filter (Hz) =	17	37	80	135	437

<u>T-File</u>	<u>Ch</u>	<u>Signal</u>	<u>Test ID</u>	<u>Sampling</u>		<u>Freq. (Hz) @ Cum. PSD Levels</u>				
2-0572	02.	AC HD1 X G'S	A-925	2048	8000	41	72	119	254	760
2-0573	03.	AC HD1 Y G'S	A-925	2048	8000	14	20	25	29	137
2-0574	04.	AC HD1 Z G'S	A-925	2048	8000	6	18	27	35	156
2-0597	02.	AC HD1 X G'S	A-926	2048	8000	10	16	31	57	977
2-0598	03.	AC HD1 Y G'S	A-926	2048	8000	16	21	31	45	852
2-0599	04.	AC HD1 Z G'S	A-926	2048	8000	10	21	37	51	854
2-0622	02.	AC HD1 X G'S	A-934	2048	8000	6	16	23	27	37
2-0623	03.	AC HD1 Y G'S	A-934	2048	8000	8	14	27	33	119
2-0624	04.	AC HD1 Z G'S	A-934	2048	8000	8	14	21	25	31
2-0696	02.	AC HD1 X G'S	A-938	2048	8000	12	21	27	33	59
2-0697	03.	AC HD1 Y G'S	A-938	2048	8000	14	20	25	29	63
2-0698	04.	AC HD1 Z G'S	A-938	2048	8000	16	23	27	31	86
2-0720	02.	AC HD1 X G'S	76B001	2048	8000	6	6	27	45	143
2-0721	03.	AC HD1 Y G'S	76B001	2048	8000	23	35	86	107	264
2-0722	04.	AC HD1 Z G'S	76B001	2048	8000	20	37	86	105	238

Appendix C


SAMPLES OF SIGNALS AND POWER DENSITY SPECTRA


This Appendix is included to provide samples of the biomechanical signals used in the filter study, and to show their power density spectra as well as the cumulative PDS functions. The label P.S.D. was inadvertently used to refer to the PDS. To conserve space, not all 450 signals and spectra are included. Those that are included are most typical of all biomechanical signals, and demonstrate the variety of responses that may be found.

The following contains a LEGEND of the features and information found on each of the subsequent graphs. The keys to these information are the circled numbers which correspond to the following.


- (1) Tape number (1 or 2) where the raw signal may be found. The data base from which these signals were obtained consisted of two magnetic tapes that are formatted in the NHTSA Biomechanics Tape Format (old version).
- (2) File number on that tape which contains the sensor data.
- (3) Channel number, i.e., the sequential order of the sensor data in the digitized and formatted test.
- (4) Test ID or reference number to which the signal belongs.
- (5) Sensor type. Here, all are accelerometer (AC) signals.
- (6) Sensor attachment location. See Appendix A for a list of these codes, or consult the NHTSA Biomechanics Tape Format guideline.
- (7) Direction of sensitive axis of the sensor.
- (8) Peak-to-peak range and units of the signal. The signal is always scaled to fit this range over the entire vertical scale.
- (9) Duration of the signal in milliseconds. The signal is always scaled to fit this duration over the entire time axis.

- (10) Number of samples in the signal.
- (11) Sampling rate, in Hertz, of the signal.
- (12) Peak value of the PDS which is used to normalized the PDS curve.
- (13) Last value of the cumulative PDS curve that occurs at the Nyquist rate or half the sampling rate described in (10) above. Note that the maximum frequency on the plots vary but are not necessarily equal to the Nyquist rate. This is done to expand the curves at low frequencies where most of the "action" takes place.
- (14) Vertical scale for both the normalized PDS and its cumulative function, which ranges from 0 to 100 percent. Note that the 50, 75, 90, and 95% levels are shown, but not the 99% level.
- (15) Frequencies at which the cumulative PDS curve crosses the four indicated levels. The fifth landmark (at 99%) is not shown for clarity, but was is listed in Appendix B.
- (16) Gains (in deciBels) corresponding to the 4 levels of the cumulative PDS.
- (17) Time history of the raw signal, which has been scaled vertically and horizontally to fit the entire plotting region. Generally, this signal would have been filtered with SAE Channel Class 1000 filter before being digitized, but is considered "unfiltered" for the purposes of this study.
- (18) The power density spectrum, obtained by normalizing the squared magnitude of the signal which, in turn, was obtained from the FFT of the signal. Note that the peak occurs, in general, at a low frequency, and that the PDS is a noisy curve which does not necessarily approach zero at high frequencies.
- (19) The cumulative PDS curve, obtained at each frequency by simple summation of the PDS values of all previous frequencies, then normalized to 100% at the last accumulated value. Note that this curve will always be positive, increasing, and monotonous, which allows successful detection of the 5 landmark levels.







T1 F2177 Ch02 Test: A-880 Sensor: AC UST X




T1 F2177 Ch02 Test: A-880 Sensor: AC UST X




T1 F2190 Ch15 Test: A-880 Sensor: AC T12 X




T1 F2190 Ch15 Test: A-880 Sensor: AC T12 X




T1 F2298 Ch03 Test: A-924 Sensor: AC LST X




T1 F2300 Ch05 Test: A-924 Sensor: AC LUR Y




T1 F2322 Ch05 Test: A-927 Sensor: AC LUR Y




T1 F2324 Ch07 Test: A-927 Sensor: AC RUR Y




T1 F2353 Ch15 Test: A-928 Sensor: AC T12 X




T1 F2353 Ch15 Test: A-928 Sensor: AC T12 X




T1 F2354 Ch16 Test: A-928 Sensor: AC T12 Y




T1 F2374 Ch15 Test: A-937 Sensor: AC T12 X




T1 F2375 Ch16 Test: A-937 Sensor: AC T12 Y




T1 F2382 Ch02 Test: 76T003 Sensor: AC UST X




T1 F2385 Ch05 Test: 76T003 Sensor: AC LUR Y




T1 F2401 Ch03 Test: 76T008 Sensor: AC T01 Z




T1 F2401 Ch03 Test: 76T008 Sensor: AC T01 Z




T1 F2403 Ch05 Test: 76T008 Sensor: AC T12 Y




T1 F2429 Ch05 Test: 76T009 Sensor: AC LUR Y




T1 F2430 Ch06 Test: 76T009 Sensor: AC RLR X




T1 F2431 Ch07 Test: 76T009 Sensor: AC RUR Y




T1 F2440 Ch16 Test: 76T009 Sensor: AC HED Y




T1 F2450 Ch05 Test: 76T010 Sensor: AC LUR Y




T1 F2470 Ch04 Test: 76T011 Sensor: AC LLR X





T1 F2471 Ch05 Test: 76T011 Sensor: AC LUR Y







T1 F2473 Ch07 Test: 76T011 Sensor: AC RUR Y






T1 F2490 Ch03 Test: 76T020 Sensor: AC T01 Z







T1 F2496 Ch09 Test: 76T020 Sensor: AC LUR Y




T1 F2534 Ch09 Test: 76T022 Sensor: AC RUR Y




T1 F2563 Ch02 Test: 76T029 Sensor: AC LLR X




T1 F2564 Ch03 Test: 76T029 Sensor: AC LUR Y




T1 F2617 Ch02 Test: 76T050 Sensor: AC LUR Y



T1 F2621 Ch06 Test: 76T050 Sensor: AC UST X



T1 F2630 Ch02 Test: 76T053 Sensor: AC LUR Y




T1 F2635 Ch07 Test: 76T053 Sensor: AC LST X


1246 Pts 6410 Hz Max P.S.D. = 2.114 Cum. = 46.73

Peak-to-Peak:
G'S = 42.87


Signal Length:
msec = 194.23




T1 F2650 Ch06 Test: 76T056 Sensor: AC UST X




T1 F2831 Ch02 Test: 77T089 Sensor: AC LUR Y



T1 F2838 Ch09 Test: 77T089 Sensor: AC T01 Y




T1 F2850 Ch02 Test: 77T092 Sensor: AC LUR Y




Peak-to-Peak:
 G'S= 279.2
 Signal Length:
 msec= 291.89


T1 F2856 Ch08 Test: 77T092 Sensor: AC T01 X




T1 F2857 Ch09 Test: 77T092 Sensor: AC T01 Y




T1 F2858 Ch10 Test: 77T092 Sensor: AC T01 Z




T1 F2860 Ch12 Test: 77T092 Sensor: AC T12 X




T1 F2861 Ch13 Test: 77T092 Sensor: AC T12 Y




T1 F2862 Ch14 Test: 77T092 Sensor: AC T12 Z




T1 F2869 Ch02 Test: 77T095 Sensor: AC LUR Y




T1 F2870 Ch03 Test: 77T095 Sensor: AC LLR X




T1 F2871 Ch04 Test: 77T095 Sensor: AC RUR Y




T1 F2872 Ch05 Test: 77T095 Sensor: AC RLR X




T1 F2873 Ch06 Test: 77T095 Sensor: AC UST X




T1 F2888 Ch02 Test: 77T098 Sensor: AC LUR Y




T1 F2889 Ch03 Test: 77T098 Sensor: AC LLR X




T1 F2890 Ch04 Test: 77T098 Sensor: AC RUR Y




T1 F2891 Ch05 Test: 77T098 Sensor: AC RLR X




T1 F2892 Ch06 Test: 77T098 Sensor: AC UST X




T1 F3425 Ch02 Test: 75A116 Sensor: AC HD1 X




T1 F3426 Ch03 Test: 75A116 Sensor: AC HD1 Y




T1 F3427 Ch04 Test: 75A116 Sensor: AC HD1 Z




T1 F3427 Ch04 Test: 75A116 Sensor: AC HD1 Z




T1 F3512 Ch02 Test: 76A144 Sensor: AC HD1 X




T1 F3513 Ch03 Test: 76A144 Sensor: AC HD1 Y




T1 F3514 Ch04 Test: 76A144 Sensor: AC HD1 Z




T1 F3515 Ch05 Test: 76A144 Sensor: AC HD2 Z




T1 F3516 Ch06 Test: 76A144 Sensor: AC HD2 X




T1 F3529 Ch06 Test: 76A145 Sensor: AC HD2 X




T2 F0005 Ch04 Test: MS 91 Sensor: AC HD2 X




T2 F0006 Ch05 Test: MS 91 Sensor: AC HD2 Y




T2 F0007 Ch06 Test: MS 91 Sensor: AC HD2 Z




T2 F0015 Ch03 Test: MS 92 Sensor: AC HD1 Z




T2 F0016 Ch04 Test: MS 92 Sensor: AC HD2 X




T2 F0016 Ch04 Test: MS 92 Sensor: AC HD2 X



T2 F0017 Ch05 Test: MS 92 Sensor: AC HD2 Y



T2 F0018 Ch06 Test: MS 92 Sensor: AC HD2 Z



T2 F1039 Ch18 Test: 82-04 Sensor: AC HED Y

2500 Pts 10000 Hz Max P.S.D.= 83.15 Cum.= 1371.

Peak-to-Peak:

G'S= 350.0

Signal Length:

msec= 249.90

dB (Hz)

-13 635

-10 376

-6 103

-3 32


P.S.D. and


Cumulative

T2 F1040 Ch19

Test: 82-04

Sensor: AC HED Z






T2 F1068 Ch18 Test: 82-05 Sensor: AC HED Y

2500 Pts 10000 Hz Max P.S.D. = 94.84 Cum. = 409.2

Peak-to-Peak:
 G'S = 94.87
 Signal Length:
 msec = 249.90



P.S.D. and
 Cumulative


T2 F1068 Ch18 Test: 82-05 Sensor: AC HED Y

2500 Pts 10000 Hz Max P.S.D.= 83.15 Cum.= 1371.

Peak-to-Peak:
G'S= 350.0
Signal Length:
msec= 249.90

dB (Hz)	%
-13 635	95
-10 376	90
-6 103	75
-3 32	50


P.S.D. and
Cumulative



T2 F1040 Ch19 Test: 82-04 Sensor: AC HED Z

2500 Pts 10000 Hz Max P.S.D.= 70.35 Cum.= 635.3

Peak-to-Peak:
G'S= 194.8
Signal Length:
msec= 249.90



P.S.D. and
Cumulative

T2 F1069 Ch19 Test: 82-05 Sensor: AC HED Z